Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/05/17

Portland Maine Yes. Google's good here.

Laurie Leader <lrl@portlandmaine

Re: 660-662 Congress Street - Retail Space Fit Out

1 message

Andre Guimond <andre@presentarchitecture.com> Fri, Jun 30, 2017 at 9:35 AM
To: Laurie Leader <lrl@portlandmaine.gov>
Cc: "Kenn Guimond (guimondgroup@aol.com)" <guimondgroup@aol.com>, Evan Erlebacher <evan@presentarchitecture.com>

Hi Laurie,

Kenn Guimond relayed your comments about providing an ADA accessible checkout counter in 660-662 Congress Street's retail space. Please note that the checkout counter shall adhere to the following ADA accessibility standards:

- At the cash register location, a section of the counter at least 36 inches long shall be not more than 36 inches above the floor

- A clear space at least 30 inches by 48 inches in front of the checkout counter will be provided to accommodate a wheelchair.

Please let me know if this is sufficient to proceed with your plan review and permit issuance.

Best regards,
Andre

Andre Guimond
State of Maine Registered Architect
PRESENT Architecture PLLC
66 W. Broadway, Suite 306
New York NY 10007
p: 207 449 8513
presentarchitecture.com
instagram

On Wed, Jun 14, 2017 at 3:44 PM, Andre Guimond <andre@presentarchitecture.com> wrote:

> Dear Portland Permitting and Inspections Department,
>
> Attached, please find our application and drawings for the final fit out of the basement and 1st floor retail unit at 660-662 Congress Street.
>
> Please feel free to reach out to us with any questions or concerns.
>
> Best regards,
> Andre
>
> ---
> Andre Guimond
> State of Maine Registered Architect
> **PRESENT Architecture PLLC**
> 66 W. Broadway, Suite 306
> New York NY 10007
> p: 207 449 8513
> presentarchitecture.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/05/17

instagram