

Mail

 More

COMPOSE

Inbox (71)

Starred

Sent Mail

Drafts (5)

ALL Building Permits

Tent/Events

CFPM Registrations

INTERDEPARTMENT...

OUTDOOR SEATING...

More

To: Jennifer Wilbur <jenniferwilbur.jw@gmail.com>

Jennifer,

I think this looks good. We request that the guy wire that supports the bracket be drilled into a mortar joint, rather than drilled into the brick itself.

I can't tell from the image what color the sign background is. Is it white? Given the soft paint scheme of the storefront, it might be nice to soften the background color a bit to pale gray. Not a requirement; just an unsolicited opinion.

Take care,

Deb


On Fri, Sep 8, 2017 at 10:49 AM, Jennifer Wilbur <jenniferwilbur.jw@gmail.com> wrote:

Good Morning Deb,

Attached is the photo mock up from the sign company. Thanks for your help!

Best Regards,
Jennifer

3 Attachments



Marteen Santerre <soulbeingllc@gmail.com>
to permitting, Jennifer, dga, Jim, guimondgroup

Sep 19 (7 days ago) ☆

Also attaching Schedule C. Thank you.