


Southern Maine Cabling

**10 Bronder Ln
Sanford, ME 04073
207-651-2918**

Hi Ben,

The new strobes are functional with the fire alarm. The current fire alarm is functional. The fire alarm isn't inspected due to the fact there is a new fire alarm system being drawn up right now.

Pete Desrochers



**Southern Maine Cabling
207-651-2918**