### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



### This is to certify that

638 CONGRESS STREET PARTNERS LLC/Patriot Mechanical LLC/Beau Montgomery

**ISSUE DATE:** 01/31/2014 **CBL:** 045 A003001

**PERMIT ID:** 2014-00014

1550E DATE: 01/31/2014

has permission to HVAC; install Fujitsu In wall heater. In basement of 644 & 646.

\*\*Please send Issued Permit, no E-mail.\*\*

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Located at

638 CONGRESS ST (644)

Fire Official

**Building Official** 

## THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

101 residential dwelling units with retail restaurant & personal services on first floor along Congress Street

# BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

### **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 01/06/2014 2014-00014 045 A003001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Same: 101 residential DU with retail, restaurant & personal services HVAC; install Fujitsu In wall heater. In basement of 644 & 646. \*\*Please send Issued Permit, no E-mail.\*\* on 1st floor along Congress Street Reviewer: Robert Wiener **Dept:** Historic **Status:** Approved w/Conditions **Approval Date:** 01/22/2014 Ok to Issue: Note: **Conditions:** 1) No exterior alterations are approved as part of this permit. 01/07/2014 **Dept:** Zoning Status: Approved **Reviewer:** Marge Schmuckal **Approval Date:** Note: Ok to Issue: **Conditions: Dept:** Building **Status:** Approved w/Conditions Reviewer: Tammy Munson 01/30/2014 **Approval Date:** Ok to Issue: Note: **Conditions:** 1) Duct penetrations shall be protected per IBC Sec. 713.1.1 & 716 and when through fire barriers, approved fire or smoke dampers or combination of, shall be installed in accordance with their listing. 2) The appliance and venting shall be installed in accordance with the UL listing, manufacturer's specifications, MUBEC 2009 and NFPA 211 3) Any modifications to existing building systems and all new systems (HVAC, electrical, plumbing) shall meet IECC 2009 or ASHRAE 90.1-2007 requirements for energy code compliance. 4) The installation must comply with the State of Maine Gas Regulations. **Dept:** Fire **Status:** Approved w/Conditions Reviewer: Craig Messinger 01/20/2014 **Approval Date:** Note: Ok to Issue: **Conditions:** 

1) All outstanding code violations shall be corrected prior to final inspection.