Location of Construction:				Permit NoQ Q 1	112	
						• + T O
Owner Address:	Lessee/Buyer's Name:	Phone:	BusinessN	ame:	PERMITIS	
P.O. Box 5065	N/A	N/A	N/A		Doublet look do	
Contractor Name:		Address: Phone:			Permit Issued:	ii n 🗸
Owner	P.O. Box 5065		799-0636			923
Past Use:	Proposed Use:	COST OF WOR		ERMIT FEE:		
		\$ 250.00		30.00		
Multifamily	Same	FIRE DEPT. 🗹		NSPECTION:		an analysis of the state of the
			Denied U	Jse Group: 1-2 Type: 53		
			VIII	BOCA95,100	Zoner CBL: 045	5-A-013
	Determination of leght	Signature:	M'/ S	ignature: Haffac	Zoning Approval:	
Proposed Project Description:	mits made prevensly	PEDESTRIAN <sup>®</sup>	ACPIVITIES	DISTRICT (P.A.D.)		10/12/99
Install Fire rated 90 min. door	on 2nd floor landing.	Action:	Approved		Special Zone o	or Reviews:
	· · Aile		Approved with	h Conditions:	□ Shoreland	espot
	mforce	さ	Denied		UWetland	2.20 4
		$\boldsymbol{\prec}_{\ldots}$				Cont Carina
		Signature:		Date:		mits
Permit Taken By: KA	Date Applied For:	-5-99			🛛 🖾 Site Plan maj 🛾	
KA					Zoning A	nneal
1. This permit application does not preclude	the Applicant(s) from meeting applicable St	tate and Federal rules				ppou.
1					□ Miscellaneous	
2. Building permits do not include plumbin					Conditional Use	e
	tarted within six (6) months of the date of iss	uance. False informa-			☐ Interpretation	
tion may invalidate a building permit and	-				Approved     Denied	
		Call for Pick	-		Denied	
		Stephen Lesnes	ki 799-0	636	Historic Pres	servation
					□Not in District o	
					Does Not Requi	ire Review
					☐ Requires Revie	w,
			PEF	PMIT ISSUED	Any Exte	riotury
			WITH	REQUIREMENTS		
	CERTIFICATION		•••••		Appoved	
I hereby certify that I am the owner of record		ork is authorized by t	he owner of rec	ord and that I have been	Approved with (	Conditions
authorized by the owner to make this application					Denied	
if a permit for work described in the application						
areas covered by such permit at any reasonab				addising to enter di	Date:	
	F		1 -			
		10-5-99				
					-	
SIGNATURE OF APPLICANT	ADDRESS:	DATE:	Р	HONE:		
						<b></b>
RESPONSIBLE PERSON IN CHARGE OF W			D	HONE:		2
KESI ONSIDLE I EKSON IN CHARGE OF V	ONIX, HILL		Г			
White	e–Permit Desk Green–Assessor's Can	arv-D.P.W. Pink-P	ublic File Ivo	orv Card-Inspector	ub	

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

ry.

## COMMENTS

						5		
1-12-01	Fim	Derr	instadd	21 111	Da Nam	in X	12	
CV				K-N LV/	part prover			
<u></u>								
								·
CBC: 4 Rennit; G	15-A	-13						
Dans to C	AG INF	2					Inspection Record	
		)			<b>T</b>	Туре		Date
					Foundation: _			
					Other:			

## THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Building or Use Permit Pre-Application** 

Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE\*\*If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building) :	141 Spring	ST OUIDI
Total Square Footage of Proposed Structure	Square Footage of Lot	ί
Tax Assessor's Chart, Block & Lot Number Chart# 45 Block# A Lot# 3	Owner: Stephen Lesineski	Telephone#: 799-0636
Owner's Address:	Lessee/Buyer's Name (If Applicable)	Cost Of Work: Fee
P.D. fox 5065		\$250°° \$ 30.00
Proposed Project Description:(Please be as specific as possible)		
Install Fire rated 90	min door on 2	Flr. Landing
Contractor's Name, Address & Telephone	snuski	Rec'd Br
Current Use: MULTI Family	Proposed Use: SAA	u

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.

•All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.


You must Include the following with you application:


1) ACopy of Your Deed or Purchase and Sale Agreement CITY OF PORTLAND, ME

2) A Copy of your Construction Contract, if available

3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.





Unless exempted by State Law, construction documents must be designed by a registered design profe

A complete set of construction drawings showing all of the following elements of construction:

Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)

- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:	Alcha	Clesneshi	Date	- 99

Building Permit Fee: \$30.00 for the 1st \$1000.cost plus \$6.00 per \$1,000.00 construction cost thereafter. Additional Site review and related fees are attached on a separate addendum

	BUILDING PERMIT REPORT					
DATE:	: 10/5/99 ADDRESS: 141 Spinis StCBL: 045-#-013					
REASC	ONFORPERMIT: Install Door					
BUILD	DING OWNER: Stephen Lesneski					
PERM	IT APPLICANT:/Contractor/					
USE GI	$ROUP\R-2\CONSTRUCTION TYPE\_5/3\$					
	ty's Adopted Building Code (The BOCA National Building Code/1996 with City Amendments) ty's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)					
	CONDITION(S) OF APPROVAL					
_	ermit is being issued with the understanding that the following conditions are met: <u>K</u>					
Approv	ed with the following conditions:					
¥ <u>1.</u> 2.	This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained (A 24 hour notice is required prior to inspection)" <u>ALL</u> LOT LINES SHALL BE CLEARLY MARKED BEFORE CALLING."					
3.	Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be covered with an approved filter membrane material.					
4.	placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2 Foundations anchors shall be a minimum of $\frac{1}{2}$ " in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)					
5.	Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.					
6. 7.	Precaution must be taken to protect concrete from freezing. Section 1908.0 It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify					
	that the proper setbacks are maintained.					
8.	8. Private garages located <u>beneath habitable rooms</u> in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. <u>Private garages attached side-by-side to rooms</u> in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)					
9.	All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211					
10.	Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.					
11.	Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 ¼" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)					
12.	Headroom in habitable space is a minimum of 7'6". (Section 1204.0)					
13.	Stair construction in <u>Use Group R-3 &amp; R-4is a minimum of 10" tread and 7 %" maximum rise</u> . All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)					
14. 15.	The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4 Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as <u>means of egress or rescue</u> they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1016.4)					

- 16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
- 17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)
- 18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
- 19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 &19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.

- 20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
- 21. The Fire Alarm System shall maintained to NFPA #72 Standard.
- 22. The Sprinkler System shall maintained to NFPA #13 Standard.
- 23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)
- 24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
- 26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
- 27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. <u>No closing in of walls until</u> <u>all electrical</u> (min.72 hours notice) <u>and plumbing inspections have been done.</u>
- 28. All requirements must be met before a final Certificate of Occupancy is issued.
- 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).
- Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
- 31. Please read and implement the attached Land Use Zoning report requirements.
- 32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.
- 33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.
- All signage, shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code 1996).
   35.

P. Samuel Hoffses, Building Inspector

cc: Lt. McDougall, PFD

Marge Schmuckal, Zoning Administrator イチメロッシュー

PSH 7/24/99

\*\*On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.



## Atlantic Pre-Hung Doors, Inc.

Warehouse Prices - Special Orders



STANLEY 1-1/2 HOUR RATED STEEL FIRE DOORS WITH EXPANDABLE FRAMES -

Effective: July 14, 1999

## BASIC UNIT INCLUDES:


--- 1-1/2 Hour "B" Rated Fire Door and Expandable Drywall Frames Per ASTM - 152. (Available in 6'8" only) -- Furnisfied in a Kd (Knockdown) Condition.

--- Steel Frame and Trim Kits Consists of Headers, Latch and Hinge Jamb Sections, Fire Resistant Stanley Weatherstrip, Door Bottom Sweep, a Thermally Broken Aluminum Threshold, a Flip-flop Strike Plate, Primed Unassembled Hinges, and Required Assembly Hardware.

--- For sizes 5-1/16" and Larger for Inswing and 6-1/16" and Larger for Outswing,

A Threshold Extender is provided.

--- Note That All Doors Are Bored with a 2-3/4" Backset



To Determine Rough Opening: Add 1" to the width and 1-1/4" to the height of the nominal door dimension