

November 30, 1979

Carlton Winslow  
19 Pine Street  
Portland, Maine

Re: 149-151 Spring Street (Carlton Court)

Sir:

Your building permit application to change the use from 19 apartments to 21 apartment units, at the above address is APPROVED subject to the following:

- (1) Pull stations for fire alarm on the first floor shall be placed at the first floor exit.
- (2) Provide 2nd means of egress from first floor units. (Chapter 314 Municipal Code) *see page 11 of plan*
- (3) Apartment separation at building #147 shall be a two (2) hour fire separation wall. *see plan*
- (4) All exit doors shall swing in the direction of exit travel. *see plan*

If I may be of further assistance, please feel free to call.

Yours truly,

*Walter W. Hilton*  
Walter Hilton  
Chief Building Inspector

S.S. Lt. Collins, Fire Prevention