



CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

July 28, 2017

<b>Responsible Party 1:</b> JOSEPH SAVUKINAS 11600 N OAK ST <i>1600 N. Oak St</i> ARLINGTON VA <del>22009</del> <i>22209</i>		
<b>Location</b> 119 STATE ST	<b>CBL</b> 045 A019001	<b>Inspection Date</b> 7/7/2017
<b>Inspector</b> Alan Greene	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b>

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 8/15/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<b>NFPA 101- 7.2.1.8.1 DOORS SHALL BE SELF-CLOSING &amp; SELF-LATCHING;</b> A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise specified by 7.2.1.8.3.	<i>10/1/17</i>
<b>NFPA 70- ARTICLE 110.12 EXPOSED WIRES;</b> Internal parts of electrical equipment, including busbars, wiring terminals, insulators, and other surfaces, shall not be damaged or contaminated by foreign materials such as paint, plaster, cleaners, abrasives, or corrosive residues. There shall be no damaged parts that may adversely affect safe operation or mechanical strength of the equipment such as parts that are broken, bent, cut, or deteriorated by corrosion, chemical reaction, or overheating. Overhead in the basement	<i>10/1/17</i>
<b>NFPA 101- 31.3.4.5.1 SMOKE DETECTOR EACH SLEEPING ROOM;</b> In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements. Owners apt	<i>8/20/17</i>
<b>CITY OF PORTLAND RULES AND REGS- CHAPTER 4.6 LABEL UNIT DOORS;</b> 4.6 Commercial suites shall be designated as approved by the FD. In single floor buildings letter designations shall be acceptable. 4.6.1 Residential units shall be designated using numerals. 4.6.2 The first numerical of each residential unit shall be the floor designation. 4.6.3 In single floor buildings the floor designation shall be omitted.	<i>8/20/17</i>

Violation	Proposed Date of Completion
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

8/15/17  
Date

Joseph Savukonas  
Responsible Party

\_\_\_\_\_  
Date

\_\_\_\_\_  
Responsible Party

**SEEN AND AGREED**

8/15/2017  
Date

Capt. Petrucci  
Fire Prevention Bureau