


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

February 15, 2018

ALAN MILLER
 PO BOX 724
 PORTLAND ME 04104

| | | |
|-----------------------------------|---|------------------------------------|
| Location 125 STATE ST | CBL 045 A021001 | Inspection Date 1/3/2018 |
| Inspector Alan Bouchard | Inspection Type FP Routine Inspection | Status Failed |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 3/02/2018.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

| Violation | Proposed Date of Completion |
|--|--|
| NFPA 101- 7.2.8.6.2 FIRE ESCAPE REQUIRES REPAIR; The authority having jurisdiction shall be permitted to approve any existing fire escape stair that has been shown by load test or other satisfactory evidence to have adequate strength. Third floor delta side escape ends at floor 2 | 5 / 28 / 18 |
| NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements. common area in all apartments requires detectors. | IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed. |
| FINAL DATE OF COMPLETED VIOLATION(S) | 5 / 28 / 18 |
| FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S) | 5 / 28 / 18 |

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

2/28/18
Date

Alan Miller
Responsible Party

Date

Responsible Party

SEEN AND AGREED

3/7/18
Date

CAPT. JBB
Fire Prevention Bureau