Portland Maine Yes. Google's good here.

Jeanie Bourke <jmb@portlandr

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/14/17

Fwd: Bathroom lock

2 messages

Adam Shepherd <adam@rippleffect.net> Thu, Apr 13, 2017 at 2:54 PM
To: Jeanie Bourke <jmb@portlandmaine.gov>

Jeanie,

This is what the folks from the church have said about the lock. Let me know if this will suffice. If not, they will put in a lock that does.

Adam
---------- Forwarded message ----------
From: **Camy Barrantes** <barrantescamy@gmail.com>
Date: Wed, Apr 12, 2017 at 6:09 PM
Subject: Bathroom lock
To: Adam Shepherd <adam@rippleffect.net>

Hi Adam,

I forgot to include this in my last email. The bathroom door has an old fashioned sliding bolt lock on the inside - like you might find on a shed. The previous tenant also had a little sign on the outside where a person could put little hanging thing that said whether it was a male or female in the bathroom. They used it that way for 25 years.

Just wanted you to know. Don't know if this would be sufficient.

Camy

--
Adam Shepherd
Rippleffect
Executive Director
(207) 791-7870 (Office)
(917) 710-0399 (Cell)
adam@rippleffect.net
www.rippleffect.net

Jeanie Bourke <jmb@portlandmaine.gov> Fri, Apr 14, 2017 at 1:45 PM
To: Adam Shepherd <adam@rippleffect.net>

Hi Adam,

I'm curious of the previous tenant, your application says it was vacant storage, previously a Theological Seminary. While the bathroom does not quite meet the code for single use, the sliding bolt could suffice for private use, and in lieu of the gender identified sign that they used, the more appropriate signage posted on the door would be "Single Use Only/Unisex".

Let me know,

Jeanie

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/14/17