

Portland, Maine



Yes. Life's good here.

Jerome F. LaMoria
Fire Chief, Fire Department

Portland Fire Department
Fire Prevention Bureau
380 Congress St
Portland, ME 04101

May 21, 2015

Dear Ms Barrantes,

This letter is to confirm we have accepted your Plan of Action for the property located on 159 State Street. Please call us at (207)-874-8400 if anything should change with this plan.

We have scheduled a re-inspection of this property for June 23, 2015.

Sincerely,

Captain David Petrucci

OFFICE USE ONLY

5/21/2015

Date Submitted

POA Completion Date

Capt. David Petrucci

Approved By (Print)

5/21/2015

Date

Plan to address life safety code issues at State Street Church

May 21, 2015

- 1. Branches used for decoration in the nursery school classroom have been removed.**
- 2. Extension cords have been removed. Electrician will install additional outlets in the room and upgrade existing outlets to newer tamper resistant ones.**
- 3. Emergency lighting, tied to the proper power circuits, will be installed to cover all levels of the two existing stairwells uses as primary and secondary egress for the nursery school.**
- 4. Lighted exit signs will be added to a door in the nursery classroom and just inside the fire doors to the upper stairwell landing just outside the nursery room.**
- 5. A lighted exit sign and emergency lighting will be added to the secondary egress door across the balcony to clearly identify the door that leads to the other stairwell.**
- 6. Additional lighted exit signs will be installed to label the outside door at ground level in each of the stairwells.**

Dan Flynn of Eldee Associates is the electrician who will do the work. He has the work scheduled to be done between June 8, 2015 and June 19, 2015.