



. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : 106 PARK STREET HC2
Building : 106 PARK STREET
Location : PORTLAND, MAINE 04104
System : #1 AREA#2
Contract :
Data File : 106 Park Street HC BASEMENT.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 106 PARK STREET Date - 11/19/12
Location - PORTLAND, MAINE 04104
Building - 106 PARK STREET System No. - #1 AREA#2
Contractor - Contract No. -
Calculated By - MIKE NOBLIT Drawing No. -
Construction: (X) Combustible () Non-Combustible Ceiling Height 7'-6"
OCCUPANCY - BASEMENT

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 6'-6"Feet Size 1/2" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 63.210 Psi Required 43.991 At Test
Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 80 Cap.
T Time of Test - @ Psi 58 Elev.
E Static (Psi) - Elev.
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
106 PARK STREET HC2


Page 2
Date 11/19/12

Pump Data:

P1 - Pump Churn Pressure : 63.8
P2 - Pump Rated Pressure : 58
P2 - Pump Rated Flow : 80
P3 - Pump Pressure @ Max Flow : 37.7
P3 - Pump Max Flow : 120

Demand:

D1 - Elevation : 2.815
D2 - System Flow : 63.2096
D2 - System Pressure : 43.991
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 63.2096
Safety Margin : 16.839



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
106 PARK STREET HC2

Page 3
Date 11/19/12

Fitting Legend																					
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
106 PARK STREET HC2

Page 4
Date 11/19/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
202	6.5	5.6	7.81	na	15.65	0.05	130	7.0
201	6.5	5.6	9.02	na	16.82	0.05	130	7.0
204	6.5	5.6	7.0	na	14.82	0.05	130	7.0
203	6.5	5.6	8.09	na	15.93	0.05	130	7.0
23	6.5		14.82	na				
22	6.5		17.41	na				
21	6.5		31.81	na				
20	6.5		38.93	na				
2	6.5		40.5	na				
1	0.0		43.97	na				
TEST	0.0		43.99	na				

The maximum velocity is 23.47 and it occurs in the pipe between nodes 22 and 21

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
106 PARK STREET HC2

Page 5
Date 11/19/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
202	15.65	1.049		14.600	7.809			K Factor = 5.60	
to		120		0.0	0.0				
201	15.65	0.0827		14.600	1.207			Vel = 5.81	
201	16.81	1.049	1T	5.0	21.330	9.016		K Factor = 5.60	
to		120		0.0	5.000	0.0			
22	32.46	0.3189		0.0	26.330	8.396		Vel = 12.05	
	0.0								
	32.46					17.412		K Factor = 7.78	
204	14.82	1.049		14.600	7.000			K Factor = 5.60	
to		120		0.0	0.0	0.0			
203	14.82	0.0747		14.600	1.091			Vel = 5.50	
203	15.92	1.049	1E	2.0	21.330	8.091		K Factor = 5.60	
to		120		0.0	2.000	0.0			
23	30.74	0.2883		0.0	23.330	6.726		Vel = 11.41	
23	0.0	1.049		0.0	9.000	14.817			
to		120		0.0	0.0	0.0			
22	30.74	0.2883		0.0	9.000	2.595		Vel = 11.41	
22	32.47	1.049	1T	5.0	8.166	17.412			
to		120		0.0	5.000	0.0			
21	63.21	1.0937		0.0	13.166	14.400		Vel = 23.47	
21	0.0	1.38	1T	6.0	18.750	31.812			
to		120		0.0	6.000	0.0			
20	63.21	0.2877		0.0	24.750	7.120		Vel = 13.56	
20	0.0	1.38	1E	3.0	2.450	38.932			
to		120		0.0	3.000	0.0			
2	63.21	0.2877		0.0	5.450	1.568		Vel = 13.56	
2	0.0	2.157	1S	13.537	6.500	40.500			
to		120		0.0	13.537	2.815			
1	63.21	0.0327		0.0	20.037	0.655		Vel = 5.55	
1	0.0	2.157		0.0	1.000	43.970			
to		150		0.0	0.0	0.0			
TEST	63.21	0.0210		0.0	1.000	0.021		Vel = 5.55	
	0.0								
	63.21					43.991		K Factor = 9.53	