SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

BASEMENT FIRE ALARM PLAN

SCALE: 1/4"=1'-0" 0 2' 4' 8'

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	4/25/2013
1	EQUIPMENT, & SHEET QTY REVISED	5/28/2013
2	REVISED PER FIRE PREV. OFFICER REVIEW	6/12/2013

CUNNINGHAM
Security Systems
10 Princes Point Road, Yarmouth, Maine 04096
Office: 207.846.3350 • Fax: 207.846.6080

FITZPATRICK ROWHOUSE
106 PARK STREET
PORTLAND, MAINE 04101
BASEMENT FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #13186
CHECKED	WAYNE B. HAWS NICET IV 90496
DATE	2/25/2013
REVISION	2
SCALE	1/4"=1'-0"

shop drawings created by:
5704 W. 4600 So.
Hooper, UT 84315
Office: 801.985.0410
UNICAD Inc.
www.unicad.net
Fire Alarm Design & Drafting Services

FA-2

SALD RESURGAM CITY OF PORTLAND MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/21/13