

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 98 Park St		Owner: Trustee, Dunbar		Phone:		Permit No: 971310	
Owner Address: 555 Park St, PO 04101		Lessee/Buyer's Name:		Phone:		Business Name:	
Contractor Name: Gentry Associates		Address: 700 Congress St, Portland, ME 04101		Phone: 774-4755		Permit Issued: DEC 17 1997	
Past Use: 4-family dwelling		Proposed Use: None		COST OF WORK: \$ 6,500.00		PERMIT FEE: \$ 45.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type: B	
Proposed Project Description: Make interior renovations Common Area - Provide new stairs to basement 1st floor rear apartment				Signature: [Signature]		Signature: [Signature]	
Permit Taken By: Evan Gentry		Date Applied For: 05 December 1997		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied: <input type="checkbox"/>		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	

PERMIT ISSUED
DEC 17 1997
CITY OF PORTLAND

**PERMIT ISSUED
WITH REQUIREMENTS**

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit


05 December 1997

SIGNATURE OF APPLICANT: Stephen Fernald ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT



COMMENTS

12/18/97 Framing ok. Guard at top of cellar stairs landing is ok for 36" because of small area covered. AR

1/22/98 Completed except for handrail on cellar stairs.

7/24/98 OK. AR

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____