



BASEMENT FIRE ALARM PLAN
 SCALE: 1/4"=1'-0"

SHEET NOTES:

- ◊ ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	6/12/2013

CUNNINGHAM
Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

91 STATE STREET
PORTLAND, MAINE 04101
BASEMENT FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #13290
CHECKED	WAYNE B. HAWES NICET IV 90496
DATE	6/11/2013
REVISION	0
SCALE	1/4"=1'-0"

Shop drawings created by
 5794 W. 4600 St.
 Hopedale, UT 84315
 Office: 801.965.0410
UNICAD Inc.
 www.unicad.net Fire Alarm Design & Drafting Services