

HYDRAULIC DESIGN INFORMATION SHEET

Name - 91 State St. Apartments Date - 6-10-13
Location - Second Floor
Building - System No. - 1 of 1
Contractor - Residential Fire Protection Contract No. - C13014
Calculated By - Drawing No. - 1 of 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 9'-0"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 10.6 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make Viking Model VK486
I Elevation at Highest Outlet - 35 Feet Size 1/2" K-Factor 4.0
G Note:Safety Margin: 19.836 Temperature Rating 155
N

Calculation Gpm Required 147.246 Psi Required 49.091 At Test
Summary C-Factor Used: Overhead 120 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 6-03-13 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 69 Elev.
R Residual (Psi) - 65 Other Well
Flow (Gpm) - 1277 Proof Flow Gpm
S Elevation - -5

P Location:
P
L Source of Information:
Y


Water Supply Curve (C)

RESIDENTIAL FIRE PROTECTION
91 State St 2nd floor 4 head

Page 2
Date 6-10-13

City Water Supply:
C1 - Static Pressure : 69
C2 - Residual Pressure: 65
C2 - Residual Flow : 1277

Demand:
D1 - Elevation : 11.261
D2 - System Flow : 47.246
D2 - System Pressure : 49.091
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 147.246
Safety Margin : 19.836



Fittings Used Summary

RESIDENTIAL FIRE PROTECTION
91 State St 2nd floor 4 head

Page 3
Date 6-10-13

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

RESIDENTIAL FIRE PROTECTION
91 State St 2nd floor 4 head

Page 4
Date 6-10-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	26.0	4	9.0	na	12.0	0.1	120	9.0
2	26.0	4	9.71	na	12.46	0.1	120	9.0
3	26.0	4	7.84	na	11.2	0.1	110	7.6
4	26.0	4	8.38	na	11.58	0.1	110	7.6
10	0.0		24.94	na				
11	0.0		21.23	na				
20	0.0		27.58	na				
21	0.0		25.2	na				
30	0.0		31.22	na				
31	0.0		28.39	na				
40	0.0		33.04	na				
41	0.0		32.64	na				
42	0.0		33.06	na				
43	0.0		33.49	na				
50	0.0		35.33	na				
51	0.0		36.24	na				
TR	1.0		38.68	na				
BR	0.0		45.93	na				
UG1	0.0		49.04	na				
UG2	-5.0		51.2	na	100.0			
TEST	0.0		49.09	na				

The maximum velocity is 10.14 and it occurs in the pipe between nodes 51 and TR

Final Calculations - Hazen-Williams

RESIDENTIAL FIRE PROTECTION
91 State St 2nd floor 4 head

Page 5
Date 6-10-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	12.00	1.049		0.0	14.000	9.000				
to		120		0.0	0.0	0.0				K Factor = 4.00
2	12.0	0.0506		0.0	14.000	0.708				Vel = 4.45
2	12.46	1.049	1T	5.0	16.000	9.708				K Factor = 4.00
to		120		0.0	5.000	11.261				
10	24.46	0.1889		0.0	21.000	3.967				Vel = 9.08
	0.0									
	24.46					24.936				K Factor = 4.90
3	11.20	1.049		0.0	12.000	7.845				K Factor = 4.00
to		120		0.0	0.0	0.0				
4	11.2	0.0445		0.0	12.000	0.534				Vel = 4.16
4	11.58	1.049	1T	5.0	4.600	8.379				K Factor = 4.00
to		120		0.0	5.000	11.261				
11	22.78	0.1656		0.0	9.600	1.590				Vel = 8.46
	0.0									
	22.78					21.230				K Factor = 4.94
10	24.46	1.049	1T	5.0	9.000	24.936				
to		120		0.0	5.000	0.0				
20	24.46	0.1889		0.0	14.000	2.644				Vel = 9.08
	0.0									
	24.46					27.580				K Factor = 4.66
11	22.78	1.049	1E	2.0	17.000	21.230				
to		120	1T	5.0	7.000	0.0				
21	22.78	0.1656		0.0	24.000	3.974				Vel = 8.46
	0.0									
	22.78					25.204				K Factor = 4.54
20	24.46	1.049	1E	2.0	12.250	27.580				
to		120	1T	5.0	7.000	0.0				
30	24.46	0.1889		0.0	19.250	3.636				Vel = 9.08
	0.0									
	24.46					31.216				K Factor = 4.38
21	22.78	1.049	1E	2.0	12.250	25.204				
to		120	1T	5.0	7.000	0.0				
31	22.78	0.1656		0.0	19.250	3.188				Vel = 8.46
	0.0									
	22.78					28.392				K Factor = 4.28
30	24.46	1.38	1T	6.0	30.750	31.216				
to		120		0.0	6.000	0.0				
40	24.46	0.0497		0.0	36.750	1.826				Vel = 5.25
	0.0									
	24.46					33.042				K Factor = 4.26
31	22.78	1.38	1T	6.0	91.500	28.392				
to		120		0.0	6.000	0.0				
41	22.78	0.0435		0.0	97.500	4.246				Vel = 4.89
	0.0									
	22.78					32.638				K Factor = 3.99
40	4.44	1.38		0.0	6.500	33.042				
to		120		0.0	0.0	0.0				
42	4.44	0.0022		0.0	6.500	0.014				Vel = 0.95

Final Calculations - Standard

RESIDENTIAL FIRE PROTECTION
91 State St 2nd floor 4 head

Page 6
Date 6-10-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 4.44									
						33.056			K Factor = 0.77	
41 to 42	22.78	1.38 120	1T	6.0 0.0	3.600 6.000	32.638 0.0				
	22.78	0.0435		0.0	9.600	0.418			Vel = 4.89	
42 to 51	4.45	1.38 120	2T	12.0 0.0	40.600 12.000	33.056 0.0				
	27.23	0.0606		0.0	52.600	3.185			Vel = 5.84	
	0.0 27.23									
						36.241			K Factor = 4.52	
40 to 43	20.02	1.38 120		0.0 0.0	13.100 0.0	33.042 0.0				
	20.02	0.0343		0.0	13.100	0.449			Vel = 4.29	
43 to 50	0.0	1.38 120	2T	12.0 0.0	41.600 12.000	33.491 0.0				
	20.02	0.0343		0.0	53.600	1.838			Vel = 4.29	
50 to 51	0.0	1.38 120	2E	6.0 0.0	20.600 6.000	35.329 0.0				
	20.02	0.0343		0.0	26.600	0.912			Vel = 4.29	
51 to TR	27.23	1.38 120	1T	6.0 0.0	11.100 6.000	36.241 -0.433				
	47.25	0.1679		0.0	17.100	2.871			Vel = 10.14	
TR to BR	0.0	1.38 120	1Z 1Zaa	3.0 0.0	7.000 3.000	38.679 5.571				* Fixed loss = 5.138
	47.25	0.1678		0.0	10.000	1.678			Vel = 10.14	
BR to UG1	0.0	1.72 150	1G 1T	0.617 6.174	75.000 6.792	45.928 0.0				
	47.25	0.0380		0.0	81.792	3.109			Vel = 6.52	
UG1 to UG2	0.0	12.34 140	1T	93.767 0.0	75.000 93.767	49.037 2.166				
	47.25	0.0		0.0	168.767	0.0			Vel = 0.13	
UG2 to TEST	100.00	6.16 140		0.0 0.0	75.000 0.0	51.203 -2.166			Qa = 100	
	147.25	0.0007		0.0	75.000	0.054			Vel = 1.59	
	0.0 147.25									
						49.091			K Factor = 21.02	