



- GENERAL NOTES**
- A.) FIRE ALARM SYSTEM WIRING SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE, APPLICABLE STATE AND LOCAL CODES AND SHAL BE COORDINATED WITH THE LOCAL AUTHORITY HAVING JURISDICTION.
 - B.) CAUTION; DO NOT CONNECT ANY POWER TO THE CONTROL PANEL (BATTERIES OR 120VAC) UNTIL ALL FIELD WIRING HAS BEEN TESTED.
 - C.) DO NOT INSTALL FIRE ALARM CONTROL PANEL OR ANY ADDRESSABLE DEVICES IN UNHEATED SPACE.
 - D.) DO NOT INSTALL ANY AC CURRENT CARRYING CONDUCTORS CLOSE TO OR IN THE SAME RACEWAY WITH FIRE ALARM SYSTEM CONDUCTORS.
 - E.) SOLID LINES REPRESENT CONNECTIONS MADE BY THE SYSTEM INSTALLER.
 - F.) ALL RELAYS ARE SHOWN IN NORMAL SUPERVISORY CONDITION. ALL RELAYS ARE FORM "C" TYPE.

- INSTALLATION NOTES**
- A.) SMOKE DETECTORS SHALL NOT BE MOUNTED ANY CLOSER THAN 3' FROM ANY AIR DUCT OPENINGS.
 - B.) ELEVATOR LOBBY SMOKE SHALL BE MOUNTED WITHIN 10' OF THE ELEVATOR DOOR.
 - C.) MANUAL PULL STATIONS SHALL BE MOUNTED PER ADA REQUIREMENTS: 48" AFF OR 42" AFF TO COMPLY WITH SIDE/FRONT REACH REQUIREMENTS.
 - D.) WALL MOUNTED HORN STROBES AND STROBES SHALL BE MOUNTED 6" FROM CEILING, OR 96" TO 80" AFF TO THE CENTER OF THE STROBE.
 - E.) HORN STROBES AND STROBES SHALL BE MOUNTED 15" FROM THE CORNER OF THE WALL. IF THIS IS NOT POSSIBLE, DEVICE SHALL BE CENTERED ON THAT WALL.
 - F.) CEILING MOUNTED HALLWAY DEVICES SHALL BE LOCATED IN A SYMMETRICAL MANNER DOWN THE CENTER OF THE HALLWAY WHEN POSSIBLE.

	SMOKE RF WIRELESS		HEAT RF WIRELESS
	SINGLE INPUT MODULE		STROBE
	SOUNDER BASE	15cd	
	HEAT DETECTOR		HORN STROBE
	DUAL MODULE	15cd	
	MANUAL PULL STATION		WEATHER PROOF HORN STROBE
	CO DETECTOR	WP 75cd	
	MICRO MODULE		MINI HORN
	SMOKE DETECTOR		CEILING MOUNT HORN STROBE
	RELAY MODULE	CL 15cd	
	ISOLATOR MODULE		SPEAKER STROBE
			SPRINKLER TAMPER SWITCH
			SPRINKLER WATERFLOW SWITCH
			CO RF WIRELESS

PROTECTION PROFESSIONALS

DATE 11/17/17

REVISION: 1.0

111 STATE STREET
PORTLAND, MAINE

SCALE: NS

SHEET: 5 OF 5

DESIGNER:
DOUG HANSEN

