



## City of Portland Fire Dept Inspection Violations

**Case Number:** FIRECo1800030      **Case Module:** Permit Management  
**Inspection Date:** 05/01/2018      **Inspection Status:** In Violation  
**Inspector:** John Brennan      **Inspection Type:** FP Routine Fire Inspection

**Job Address:** 152 State St , The Portland Club  
Portland, ME 04102      **Parcel Number:** 045 C005001

**Contact Type**      **Company Name**  
The Portland Club

**Reinspection Date & Time:**  
May 25, 2018 1:00om

**Please contact the Fire Prevention Bureau at 874-8400 if you have questions about your reinspection. If the violations are not correct at the time of reinspection, you will be charged a \$150 failed reinspection fee.**

### Noncompliance

| Code Name  | Comments | Deadline   |
|--|----------|------------|
| PFD Rules, 5.10.2<br>Fire Alarm Sticker Required   |          | 05/25/2018 |
| All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company. |          |            |