CITY OF PORTLAND, MAINE · REGULAR
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/07/13

Plan North

KEY
- DOOR MUST HAVE CLOSER
- 1 HR. RATED DOOR W/ CLOSER. DOOR MUST SWING IN DIRECTION OF TRAVEL

keyed notes:
10,11,12,13,14,15

MERCY HOSPITAL
MORRISON HOUSE: 148 STATE ST.

SECOND FLOOR

SCALE: 1/8" = 1'-0"

FA 2 - Second Floor