REVIEWED FOR CODE COMPLIANCE
CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/07/13

Plan North

KEY
- DOOR MUST HAVE CLOSER
- 1 HR. RATED DOOR W/ CLOSER. DOOR MUST SWING IN DIRECTION OF TRAVEL

keyed notes:
3, 4

MERCY HOSPITAL
MORRISON HOUSE: 148 STATE ST.

FIRST FLOOR

SCALE: 1/8" = 1'-0"

LEGEND

FACP - fire alarm panel
F - Pull Station
F - Horn Strobe (WP = weather proof)
S - Strobe
S - Smoke Detector

FA.1 - FIRST FLOOR