



NOTE:

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- PROVIDE 3/4" EMT CONDUIT IN WALL, STUBBED INTO CEILING SPACE, FOR EACH NEW COMMUNICATIONS AND SECURITY DEVICE.

KEYED NOTE:

- 1 EXISTING EXIT SIGN TO REMAIN. FILL IN DIRECTIONAL CHEVRONS.
- PROVIDE NEW FIRE ALARM DEVICE TO MATCH EXISTING. CONNECT NEW DEVICE INTO EXISTING SYSTEM.
- (3) REINSTALL EXISTING DEVICE SAVED UNDER DEMOLITION WORK.
- PROVIDE NEW EXIT SIGN TO MATCH EXISTING. CONNECT INTO EXISTING LIFE SAFETY LIGHTING CIRCUIT.
- (5) POWER FOR NEW DOOR SECURITY HARDWARE.
- PROVIDE 120V, 20A CIRCUIT FROM NEAREST EQUIPMENT BRANCH PANEL.
- PROVIDE 120V, 20A CIRCUIT FROM NEAREST NORMAL BRANCH PANEL.
- (8) PROVIDE 120V, 20A CIRCUIT FROM NEAREST CRITICAL BRANCH PANEL.

4 Fore Street/P.O. Box 618
Portland, Maine 04104
tel. (207) 772–3846
fax. (207) 772–1070
www.smrtinc.com

MERCY STATE STREET 3B MODIFICATIONS PORTLAND, MAINE

PERMIT 15 06/10/ FOR ISSUE SCALE: 1/4" = 1'-0"

PROJECT MANAGER: JC/DRAWN BY: **RBB** WRH A/E OF RECORD: EP101-15098 CAD FILE:

PROJECT NO:

DATE: SHEET TITLE:

ELECTRICAL NEW WORK PLAN

SHEET No.

EP101 COPYRIGHT 2013 SMRT INC

15098

6/10/15