Conditions Section:

Add New Condition From Default List | Add New Condition | Delete Condition | Monitoring | Close

Condition Date: 6/7/2016
Status: Final
Notes:

Windows are approved as amended, with six windows on the Pine Street face to be 6/6 simulated divided lights - all of the front windows except the three in the second floor bay. Muntins are understood to be 3/4" wide.

Condition Type
Compliance Needed By:
Compliance Date:
Sign Off:

Condition Date: 6/7/2016
Status: Final
Notes:

Screens may be full screens provided they are "Truscene" high transparency screens. If screens are conventional screens, they must be half screens.

Condition Type
Compliance Needed By:
Compliance Date:
Sign Off:

Condition Date: 6/7/2016
Status: Final
Notes:

Window glass is to appear clear, non-reflective, and untinted, with a visual transmittance ratio of .7 or greater.

Condition Type
Compliance Needed By:
Compliance Date:
Sign Off:

Condition Date: 6/7/2016
Status: Final
Notes:

Window measurements for new windows shall fill the masonry openings as fully as possible.

Condition Type
Compliance Needed By:
Compliance Date:
Sign Off: