

PERMIT ISSUED

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0335	Issue Date: MAR 30 2006	CEL: 045 E005001
-----------------------	----------------------------	---------------------

Location of Construction: 110 WINTER ST	Owner Name: KEEFE JILL	Owner Address: 15 BLYTH CT	Phone:
Business Name:	Contractor Name: Phil Snyder	Contractor Address: P.O. Box 665 Gorham	Phone:
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: R-6

Past Use: Residential/ 4 Family	Proposed Use: Residential/ 4 Family/ install a Burham V84 replacement boiler	Permit Fee: \$66.00	Cost of Work: \$4,875.00	CEO District: 2
Proposed Project Description: install a Burham V84 replacement boiler <i>legal use: 4 residential AL condo conversions</i> <i>#06-0335</i>		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>Install to NFPA 31</i> Signature: <i>Greg Lass</i>	INSPECTION: Use Group: <i>R2</i> Type: <i>5B</i> <i>JBC 2003</i> Signature: <i>JM 3/29/06</i>	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____				

Permit Taken By: ldobson	Date Applied For: 03/13/2006	Zoning Approval		
-----------------------------	---------------------------------	------------------------	--	--

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> <i>ok with conditions</i> Date: <i>3/13/06</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <i>Any exterior work requires SA separate review and approval</i> Date: _____
--	---	---	--

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 4585 Use of Building Ap + 4unit Date 3/13/06
 Name and address of owner of appliance JILL KEEFE 110 WINTER ST PH 1D
 Installer's name and address PHIL SNYDER P.O. Box 605 Gorham Me 04038
 Telephone _____

Location of appliance:

- Basement Floor
 Attic Roof

Type of Fuel:

- Gas Oil Solid

Appliance Name: Burham V84

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # MS8476
 Solid Fuel # _____
 Oil # _____
 Gas # _____
 Other _____

Type of Chimney:

- Masonry Lined
 Factory built STAINLESS Steel

- Metal
 Factory Built U.L. Listing # _____

R Direct Vent Type _____ UL# _____

Type of Fuel Tank

- Oil
 Gas

Size of Tank 27.5

Number of Tanks 1

Distance from Tank to Center of Flame 8' feet.

Cost of Work: \$ 4875.00

Permit Fee: \$ 666/00

Approved

Approved with Conditions

- See attached letter or requirement

Fire: _____
 Ele.: _____
 Bldg.: _____

Inspector's Signature

Date Approved

Signature of Installer

[Handwritten Signature]

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0335	Date Applied For: 03/13/2006	CBL: 045 E005001
------------------------------	--	----------------------------

Location of Construction: 110 WINTER ST	Owner Name: KEEFE JILL	Owner Address: 15 BLYTH CT	Phone:
Business Name:	Contractor Name: Phil Snyder	Contractor Address: P.O. Box 665 Gorham	Phone:
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Residential/ 4 Family/ install a Burharn VS4 replacement boiler	Proposed Project Description: install a Burham V84 replacement boiler
---	---



Dept: Building **Status:** Approved **Reviewer:** Tom Markley **Approval Date:** 03/29/2006

Note: **Ok to Issue:**

1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 03/17/2006

Note: **Ok to Issue:**

1) Install to comply with NFPA 31

