

---

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> Sattin Neil E		<b>Inspector</b> Marland Wing	<b>Inspection Date</b> 6/24/1999
<b>Locatation</b> 147 Brackett St	<b>CBL</b> 045 E029001	<b>Status</b> Green 0-4 Violations	<b>Inspection Type</b> Housing-Housing Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-108.1	Exterior			right wall	
<b>Violation:</b>					
<b>Notes:</b> Right wall missing shingles					
2) 6-108.4	Exterior			right stairs	
<b>Violation:</b>					
<b>Notes:</b> Right stairs loose tread					
3) 6-113.5	Interior	2		front apt	
<b>Violation:</b>					
<b>Notes:</b> Front apt. has inoperable smoke detector					
4) 6-113.5	Interior			Basement	
<b>Violation:</b>					
<b>Notes:</b> Cellar electrical panels inadeqate cover					

**Comments:**