

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

HOLMES HAZEL G BOYD & MATHEW C HOLMES JTS

Located at

167 BRACKETT ST

PERMIT ID: 2016-02872

ISSUE DATE: 01/13/2017

CBL: 045 E034001

has permission to **For the installation of a gas boiler (IBC Better Boiler HC Series) with PolyPro venting.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02872	Date Applied For: 11/15/2016	CBL: 045 E034001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Single family home	Proposed Project Description: For the installation of a gas boiler (IBC Better Boiler HC Series) with PolyPro venting.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Jennifer Thompson Approval Date: 11/30/2016				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) The installation of the equipment and products shall be done per the manufacturers specifications.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 01/13/2017				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) A Carbon Monoxide (CO) alarm shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) The installation must comply with UL, the Manufacturers' Listing, MUBEC (IRC, 2009), and State of Maine Gas Regulations.				
M1804.2.5 Direct vent terminations. Vent terminals for direct-vent appliances shall be installed in accordance with the manufacturer's installation instructions.				
Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messinger Approval Date: 12/05/2016				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Boiler Protection is required				
2) Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code.				
3) Shall meet the requirements of 2009 NFPA 1 Fire Code.				