DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

REDFERN LWS LLC

Located at

40 PINE ST

PERMIT ID: 2014-02896

ISSUE DATE: 01/13/2015

CBL: 045 E042001

has permission to For the installation of an addressable fire alarm system (Notifier by Honeywell) and AES radio masterbox for "West End Place".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Located at: 40 PINE ST **PERMIT ID:** 2014-02896 CBL: 045 E042001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Fire

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2014-02896

Date Applied For: 12/17/2014

CBL:

045 E042001

Proposed Use:

Same: Two retail suites and parking on First Floor with 39 residential apartments above.

Proposed Project Description:

For the installation of an addressable fire alarm system (Notifier by Honeywell) and AES radio masterbox for "West End Place".

Dept: Historic

Status: Approved w/Conditions

Reviewer: Robert Wiener

Approval Date:

01/12/2015

Ok to Issue:

Ok to Issue:

Note: Conditions:

1) Knox Box is to be a recessed model.

Dept: Zoning

Status: Approved w/Conditions

Reviewer: Tammy Munson

Approval Date:

01/02/2015

Note:

Conditions:

1) This approves the installation of the system only. It does not verify the legal uses of the porperty.

Dept: Fire

Note:

Status: Approved w/Conditions

Reviewer: Craig Messinger

Approval Date:

01/06/2015

Ok to Issue:

Conditions:

1) The fire alarm system shall have a new fire alarm inspection sticker.

2) The installation shall comply with the following:

City of Portland Chapter 10, Fire Prevention and Protection;

NFPA 1, Fire Code (2009 edition), as amended by City Code;

NFPA 101, Life Safety Code (2009 edition), as amended by City Code;

City of Portland Fire Department Rules and Regulations;

NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine

- 3) All smoke alarms shall be photoelectric.
- 4) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 5) A copy of the required state sprinkler permit with RMS signoff shall be provided prior to the final inspection.
- 6) System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule.