

**... Fire Protection by Computer Design**

SPRINKLER SYSTEMS INC.  
4 AVON STREET  
P O BOX 1285  
LEWISTON, ME. 04243  
207-782-0104

Job Name : WEST END APTS. WET SYSTEM AREA 1  
Building : NEW  
Location : 44 Pine Street Portland, Maine  
System : 1 Wet  
Contract : 13-058  
Data File : West End Apts Wet System Area 1.WXF

Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 1 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Retail Space

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (x) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

E				
M	Area of Sprinkler Operation	- 900	System Type	Sprinkler/Nozzle
	Density	- .20	(x) Wet	Make RELIABLE
D	Area Per Sprinkler	- 115	( ) Dry	Model F1FR56
E	Elevation at Highest Outlet	- 153	( ) Deluge	Size 1/2" x 1/2"
S	Hose Allowance - Inside	- 0	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside	- 250		

N Note

Calculation Flow Required - 258.36 Press Required - 38.406 AT BASE  
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - 04/25/14 Cap. -  
 T Time of Test - AM Rated Cap.- Elev.-  
 E Static Press - 54 @ Press -  
 R Residual Press - 40 Elev. - Well  
 Flow - 838 Proof Flow  
 S Elevation - 143.0'

U Location - BRACKETT STREET

P Source of Information - OWNER AND WATER DISTRICT

C Commodity Class Location  
 O Storage Ht. Area Aisle W.  
 M Storage Method: Solid Piled % Palletized % Rack  
 M ( ) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
 S R ( ) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
 T A ( ) Mult. Row ( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G Horizontal Barriers Provided:  
 E

# Fittings Used Summary

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 2  
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 3  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	16.87	na	23.0	0.2	115	7.0
14	153.0	K = K @ ARM	20.0	na	23.99			
12	153.0	K = K @ ARM	19.99	na	23.98			
13	153.0		20.25	na				
15	153.0		20.25	na				
10	153.0	K = K @ ARM	19.59	na	23.74			
7	153.0	K = K @ ARM	19.11	na	23.45			
8	153.0	K = K @ ARM	19.15	na	23.48			
9	153.0	K = K @ ARM	19.3	na	23.57			
5	153.0	K = K @ ARM	19.54	na	23.71			
1	153.0	K = K @ ARM	18.39	na	23.0			
2	153.0	K = K @ ARM	18.43	na	23.03			
3	153.0	K = K @ ARM	18.57	na	23.12			
4	153.0	K = K @ ARM	18.88	na	23.31			
6	153.0		19.82	na				
11	153.0		19.88	na				
16	153.0		20.27	na				
17	164.25		16.28	na				
18	164.25		19.5	na				
19	164.25		20.67	na				
20	152.75		26.07	na				
TWR	152.75		26.84	na				
TAV	149.0		31.53	na				
BWR	146.0		33.67	na				
BKFL	146.0		34.14	na				
BASE	143.0		38.41	na				
HOSE	143.0		38.69	na	250.0			
TEST	143.0		39.04	na				

The maximum velocity is 8.54 and it occurs in the pipe between nodes TYP and ARM

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 4  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to ARM	23.00 23.0	1.049 120.0 0.1684	1E 1T	2.0 5.0 0.0	2.000 7.000 9.000	16.869 0.0 1.516			K Factor = 5.60	
	0.0 23.00									
						18.385			K Factor = 5.36	
14 to 15	23.99 23.99	1.682 120.0 0.0182	1T	9.9 0.0 0.0	3.750 9.900 13.650	19.997 0.0 0.249			K Factor @ node ARM	
	0.0 23.99									
						20.246			K Factor = 5.33	
12 to 13	23.98 23.98	1.682 120.0 0.0182	1T	9.9 0.0 0.0	4.250 9.900 14.150	19.988 0.0 0.258			K Factor @ node ARM	
13 to 15	0.0 23.98	4.26 120.0 0.0		0.0 0.0 0.0	1.000 0.0 1.000	20.246 0.0 0.0				Vel = 0.54
15 to 16	23.99 47.97	4.26 120.0 0.0007	1T	26.334 0.0 0.0	2.250 26.334 28.584	20.246 0.0 0.021				Vel = 1.08
	0.0 47.97									
						20.267			K Factor = 10.66	
10 to 11	23.74 23.74	1.682 120.0 0.0180	1T	9.9 0.0 0.0	6.250 9.900 16.150	19.586 0.0 0.290			K Factor @ node ARM	
	0.0 23.74									
						19.876			K Factor = 5.32	
7 to 8	23.45 23.45	2.157 120.0 0.0052		0.0 0.0 0.0	8.000 0.0 8.000	19.111 0.0 0.042			K Factor @ node ARM	
8 to 9	23.47 46.92	2.157 120.0 0.0189		0.0 0.0 0.0	8.000 0.0 8.000	19.153 0.0 0.151			K Factor @ node ARM	
9 to 11	23.57 70.49	2.157 120.0 0.0400	1T	12.307 0.0 0.0	2.000 12.307 14.307	19.304 0.0 0.572			K Factor @ node ARM	
	0.0 70.49									
						19.876			K Factor = 15.81	
5 to 6	23.71 23.71	1.682 120.0 0.0179	1T	9.9 0.0 0.0	6.250 9.900 16.150	19.535 0.0 0.289			K Factor @ node ARM	
	0.0 23.71									
						19.824			K Factor = 5.33	
1 to 2	23.00 23.0	2.157 120.0 0.0051		0.0 0.0 0.0	8.000 0.0 8.000	18.385 0.0 0.041			K Factor @ node ARM	

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 5  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
2 to 3	23.03 46.03	2.157 120.0 0.0181		0.0 0.0	8.000 0.0	18.426 0.0			K Factor @ node ARM	
3 to 4	23.11 69.14	2.157 120.0 0.0386		0.0 0.0	8.000 0.0	18.571 0.0			K Factor @ node ARM	
4 to 6	23.31 92.45	2.157 120.0 0.0660	1T	12.307 0.0	2.000 12.307	18.880 0.0			K Factor @ node ARM	
6 to 11	23.71 116.16	4.26 120.0 0.0037		0.0 0.0	14.000 0.0	19.824 0.0				Vel = 2.61
11 to 16	94.23 210.39	4.26 120.0 0.0110	1T	26.334 0.0	9.250 26.334	19.876 0.0				Vel = 4.74
16 to 17	47.97 258.36	4.26 120.0 0.0161	1E 1T	13.167 26.334	15.500 39.501	20.267 -4.872				Vel = 5.82
17 to 18	0.0 258.36	4.26 120.0 0.0161	2E 1T	26.334 26.334	148.000 52.668	16.278 0.0				Vel = 5.82
18 to 19	0.0 258.36	4.26 120.0 0.0161	3E	39.501 0.0	33.000 39.501	19.503 0.0				Vel = 5.82
19 to 20	0.0 258.36	4.26 120.0 0.0161	1E	13.167 0.0	12.750 13.167	20.668 4.981				Vel = 5.82
20 to TWR	0.0 258.36	4.26 120.0 0.0161	1E 1T	13.167 26.334	9.000 39.501	26.065 0.0				Vel = 5.82
TWR to TAV	0.0 258.36	4.26 120.0 0.0160	1Fsp	0.0 0.0	3.500 0.0	26.845 4.624			* Fixed loss = 3	Vel = 5.82
TAV to BWR	0.0 258.36	4.26 120.0 0.0161	1B 1T	15.8 26.334	1.000 51.351	31.525 1.299				Vel = 5.82
BWR to BKFL	0.0 258.36	4.26 120.0 0.0161	1T	26.334 0.0	3.000 26.334	33.666 0.0				Vel = 5.82
BKFL to BASE	0.0 258.36	4.026 120.0 0.0220	1Zac	0.0 0.0	1.000 0.0	34.137 4.247			* Fixed loss = 2.948	Vel = 6.51
BASE to HOSE	0.0 258.36	6.16 140.0 0.0020	1E 1T 1G	20.084 43.037 4.304	75.000 67.425 142.425	38.406 0.0 0.285				Vel = 2.78

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 6  
Date

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HOSE	250.00	6.16	0.0	50.000	38.691		Qa = 250		
to		140.0	0.0	0.0	0.0				
TEST	508.36	0.0070	0.0	50.000	0.351		Vel = 5.47		
	0.0								
	508.36				39.042		K Factor = 81.36		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 1

Page 7  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 4.331  
D2 - System Flow : 258.356  
D2 - System Pressure : 39.042  
Hose ( Demand ) : 250  
D3 - System Demand : 508.356  
Safety Margin : 9.405





Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 2 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 3 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 288	( ) Dry	Model F1RES44
E	Elevation at Highest Outlet - 184	( ) Deluge	Size 3/8" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.4
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 54.09 Press Required - 48.878 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U Location - BRACKETT STREET

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 2

Page 9  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
401	184.0	4.4	16.57	na	17.91	0.05	256	13.3
401A	174.5		23.0	na				
403	184.0	4.4	17.01	na	18.15	0.05	256	13.3
402	184.0	4.4	16.8	na	18.03	0.05	288	16.8
403T	184.0		17.61	na				
403A	174.5		23.32	na				
305	174.5		23.44	na				
306	174.5		24.07	na				
319	174.5		25.51	na				
320	174.5		26.72	na				
321	174.5		27.04	na				
424T	174.5		27.33	na				
3A	174.5		28.0	na				
19	164.25		32.69	na				
20	152.75		37.69	na				
TWR	152.75		37.74	na				
TAV	149.0		42.37	na				
BWR	146.0		43.71	na				
BKFL	146.0		43.74	na				
BASE	143.0		48.88	na				
HOSE	143.0		48.89	na				
TEST	143.0		48.9	na				

The maximum velocity is 7.61 and it occurs in the pipe between nodes 403T and 403A

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 2

Page 10  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
401 to 401A	17.91	1.101 150.0	2T 2E	19.125 7.65	15.000 26.776	16.565 4.114		K Factor = 4.40	
401A to 305	17.91	0.0555 1.394 150.0		0.0 9.523 0.0	41.776 15.500 9.523	2.317 22.996 0.0		Vel = 6.04	
0.0 17.91						23.436		K Factor = 3.70	
403 to 403T	18.15	1.101 150.0	1T	9.563 0.0	1.000 9.562	17.008 0.0		K Factor = 4.40	
0.0 18.15		0.0568		0.0	10.562	0.600		Vel = 6.12	
0.0 18.15						17.608		K Factor = 4.33	
402 to 403T	18.03	1.101 150.0	1E 1T	3.825 9.563	1.000 13.387	16.800 0.0		K Factor = 4.40	
403T to 403A	18.03	0.0562 1.394 150.0		0.0 4.762 9.523	14.387 10.500 14.284	0.808 17.608 4.114		Vel = 6.08	
403A to 305	36.18	0.0646 2.003 150.0		0.0 0.0 0.0	24.784 10.250 0.0	1.601 23.323 0.0		Vel = 7.61	
305 to 306	17.91	2.003 150.0	1T	12.965 0.0	14.250 12.965	23.436 0.0		Vel = 3.68	
306 to 319	54.09	0.0233 2.157 120.0		0.0 0.0 0.0	27.215 59.000 0.0	0.633 24.069 0.0		Vel = 5.51	
319 to 320	54.09	0.0245 2.157 120.0		0.0 12.307 0.0	59.000 37.000 12.307	1.445 25.514 0.0		Vel = 4.75	
320 to 321	54.09	0.0245 2.157 120.0	1E	0.0 6.153 0.0	49.307 6.750 6.153	1.208 26.722 0.0		Vel = 4.75	
321 to 424T	54.09	0.0245 2.157 120.0		0.0 0.0 0.0	12.903 12.000 0.0	0.316 27.038 0.0		Vel = 4.75	
424T to 3A	54.09	0.0245 2.157 120.0	2E	0.0 12.307 0.0	12.000 15.000 12.307	0.294 27.332 0.0		Vel = 4.75	
3A to 19	54.09	0.0245 2.157 120.0		0.0 0.0 0.0	27.307 10.250 0.0	0.669 28.001 4.439		Vel = 4.75	
19 to 20	54.09	0.0009 4.26 120.0	1E	0.0 13.167 0.0	10.250 12.750 13.167	0.251 32.691 4.981		Vel = 4.75	
				0.0	25.917	0.023		Vel = 1.22	

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 2

Page 11  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
20 to TWR	0.0 54.09	4.26 120.0 0.0009	1E 13.167 1T 26.334	9.000 39.501 48.501	37.695 0.0 0.043		Vel = 1.22		
TWR to TAV	0.0 54.09	4.26 120.0 0.0009	1Fsp 0.0 0.0 0.0	3.500 0.0 3.500	37.738 4.624 0.003		* Fixed loss = 3 Vel = 1.22		
TAV to BWR	0.0 54.09	4.26 120.0 0.0009	1B 15.8 1T 26.334 1Eq 9.217	1.000 51.351 52.351	42.365 1.299 0.047		Vel = 1.22		
BWR to BKFL	0.0 54.09	4.26 120.0 0.0009	1T 26.334 0.0 0.0	3.000 26.334 29.334	43.711 0.0 0.026		Vel = 1.22		
BKFL to BASE	0.0 54.09	4.026 120.0 0.0020	1Zac 0.0 0.0 0.0	1.000 0.0 1.000	43.737 5.139 0.002		* Fixed loss = 3.84 Vel = 1.36		
BASE to HOSE	0.0 54.09	6.16 140.0 0.0001	1E 20.084 1T 43.037 1G 4.304	75.000 67.425 142.425	48.878 0.0 0.016		Vel = 0.58		
HOSE to TEST	0.0 54.09	6.16 140.0 0.0001	0.0 0.0 0.0	50.000 0.0 50.000	48.894 0.0 0.005		Vel = 0.58		
	0.0 54.09				48.899		K Factor = 7.74		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 2

Page 12  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 17.757  
D2 - System Flow : 54.089  
D2 - System Pressure : 48.899  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 54.089  
Safety Margin : 5.013



Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 3 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 4 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 256	( ) Dry	Model F1RES44
E	Elevation at Highest Outlet - 184	( ) Deluge	Size 3/8" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.4
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 66.54 Press Required - 47.046 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U  
 P Location - BRACKETT STREET

P  
 L Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 3

Page 14  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
407	184.0	4.4	13.9	na	16.4	0.05	256	13.3
408	174.5		19.37	na				
405	184.0	4.4	13.47	na	16.15	0.05	256	13.3
406	184.0	4.4	13.3	na	16.05	0.05	256	13.3
406T	184.0		13.95	na				
406A	174.5		19.26	na				
313	174.5		19.72	na				
314	174.5		20.07	na				
316	174.5		20.09	na				
411T	174.5		21.12	na				
317	174.5		22.14	na				
318	174.5		22.43	na				
409	184.0	4.4	16.63	na	17.95	0.05	256	13.3
410	174.5		22.16	na				
410T	174.5		22.6	na				
306	174.5		22.68	na				
319	174.5		22.86	na				
320	174.5		24.63	na				
321	174.5		25.09	na				
424T	174.5		25.52	na				
3A	174.5		26.51	na				
19	164.25		31.31	na				
20	152.75		36.33	na				
TWR	152.75		36.39	na				
TAV	149.0		41.02	na				
BWR	146.0		42.39	na				
BKFL	146.0		42.43	na				
BASE	143.0		47.05	na				
HOSE	143.0		47.07	na				
TEST	143.0		47.08	na				

The maximum velocity is 6.77 and it occurs in the pipe between nodes 406T and 406A

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 3

Page 15  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
407 to 408	16.40 16.4	1.101 150.0 0.0471	1E 1T	3.825 9.563 0.0	15.500 13.387 28.887	13.895 4.114 1.362			K Factor = 4.40 Vel = 5.53	
408 to 316	0.0 16.4	1.101 150.0 0.0472	1T	9.563 0.0 0.0	5.750 9.562 15.312	19.371 0.0 0.722			Vel = 5.53	
	0.0 16.40					20.093			K Factor = 3.66	
405 to 406T	16.15 16.15	1.101 150.0 0.0457	1T	9.563 0.0 0.0	1.000 9.562 10.562	13.468 0.0 0.483			K Factor = 4.40 Vel = 5.44	
	0.0 16.15					13.951			K Factor = 4.32	
406 to 406T	16.05 16.05	1.101 150.0 0.0452	1E 1T	3.825 9.563 0.0	1.000 13.387 14.387	13.300 0.0 0.651			K Factor = 4.40 Vel = 5.41	
406T to 406A	16.14 32.19	1.394 150.0 0.0521	2E	9.523 0.0 0.0	13.500 9.523 23.023	13.951 4.114 1.199			Vel = 6.77	
406A to 313	0.0 32.19	1.394 150.0 0.0520		0.0 0.0 0.0	8.750 0.0 8.750	19.264 0.0 0.455			Vel = 6.77	
313 to 314	0.0 32.19	1.598 150.0 0.0267		0.0 0.0 0.0	13.000 0.0 13.000	19.719 0.0 0.347			Vel = 5.15	
314 to 316	0.0 32.19	1.598 150.0 0.0270		0.0 0.0 0.0	1.000 0.0 1.000	20.066 0.0 0.027			Vel = 5.15	
316 to 411T	16.41 48.6	2.003 150.0 0.0191		0.0 0.0 0.0	54.000 0.0 54.000	20.093 0.0 1.030			Vel = 4.95	
411T to 317	0.0 48.6	2.003 150.0 0.0191	1T	12.965 0.0 0.0	40.500 12.965 53.465	21.123 0.0 1.020			Vel = 4.95	
317 to 318	0.0 48.6	2.003 150.0 0.0191		0.0 0.0 0.0	15.000 0.0 15.000	22.143 0.0 0.286			Vel = 4.95	
318 to 319	0.0 48.6	2.003 150.0 0.0191	1T	12.965 0.0 0.0	9.500 12.965 22.465	22.429 0.0 0.428			Vel = 4.95	
	0.0 48.60					22.857			K Factor = 10.17	
409 to 410	17.95 17.95	1.101 150.0 0.0557	1E 1T	3.825 9.563 0.0	12.000 13.387 25.387	16.634 4.114 1.414			K Factor = 4.40 Vel = 6.05	



Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 3

Page 16  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
410 to 410T	0.0 17.95	1.394 150.0 0.0177	1E 4.762 1T 9.523	10.500 14.284	22.162 0.0				
				24.784	0.438		Vel = 3.77		
410T to 306	0.0 17.95	2.157 120.0 0.0032	0.0 0.0	24.000 0.0	22.600 0.0				
				24.000	0.076		Vel = 1.58		
306 to 319	0.0 17.95	2.157 120.0 0.0032	0.0 0.0	57.000 0.0	22.676 0.0				
				57.000	0.181		Vel = 1.58		
319 to 320	48.59 66.54	2.157 120.0 0.0359	1T 12.307 0.0	37.000 12.307	22.857 0.0				
				49.307	1.772		Vel = 5.84		
320 to 321	0.0 66.54	2.157 120.0 0.0360	1E 6.153 0.0	6.750 6.153	24.629 0.0				
				12.903	0.464		Vel = 5.84		
321 to 424T	0.0 66.54	2.157 120.0 0.0359	0.0 0.0	12.000 0.0	25.093 0.0				
				12.000	0.431		Vel = 5.84		
424T to 3A	0.0 66.54	2.157 120.0 0.0359	2E 12.307 0.0	15.000 12.307	25.524 0.0				
				27.307	0.981		Vel = 5.84		
3A to 19	0.0 66.54	2.157 120.0 0.0360	0.0 0.0	10.250 0.0	26.505 4.439				
				10.250	0.369		Vel = 5.84		
19 to 20	0.0 66.54	4.26 120.0 0.0013	1E 13.167 0.0	12.750 13.167	31.313 4.981				
				25.917	0.033		Vel = 1.50		
20 to TWR	0.0 66.54	4.26 120.0 0.0013	1E 13.167 1T 26.334	9.000 39.501	36.327 0.0				
				48.501	0.064		Vel = 1.50		
TWR to TAV	0.0 66.54	4.26 120.0 0.0011	1Fsp 0.0 0.0	3.500 0.0	36.391 4.624			* Fixed loss = 3	
				3.500	0.004		Vel = 1.50		
TAV to BWR	0.0 66.54	4.26 120.0 0.0013	1B 15.8 1T 26.334	1.000 51.351	41.019 1.299				
				52.351	0.069		Vel = 1.50		
BWR to BKFL	0.0 66.54	4.26 120.0 0.0013	1T 26.334 0.0	3.000 26.334	42.387 0.0				
				29.334	0.038		Vel = 1.50		
BKFL to BASE	0.0 66.54	4.026 120.0 0.0020	1Zac 0.0 0.0	1.000 0.0	42.425 4.619			* Fixed loss = 3.32	
				1.000	0.002		Vel = 1.68		
BASE to HOSE	0.0 66.54	6.16 140.0 0.0002	1E 20.084 1T 43.037	75.000 67.425	47.046 0.0				
				142.425	0.024		Vel = 0.72		

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 3

Page 17  
Date

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HOSE	0.0	6.16	0.0	50.000	47.070				
to		140.0	0.0	0.0	0.0				
TEST	66.54	0.0002	0.0	50.000	0.008		Vel = 0.72		
	0.0								
	66.54				47.078		K Factor = 9.70		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 3

Page 18  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 17.757  
D2 - System Flow : 66.541  
D2 - System Pressure : 47.078  
Hose ( Demand ) :  
D3 - System Demand : 66.541  
Safety Margin : 6.793



Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 4 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 3 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 288	( ) Dry	Model F1RES44
E	Elevation at Highest Outlet - 184	( ) Deluge	Size 3/8" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.4
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 54.32 Press Required - 45.238 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U Location - BRACKETT STREET

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	%	Palletized % Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R	K	Flue Spacing	Clearance:Storage to Ceiling
A		Longitudinal	Transverse

E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 4

Page 20  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
414	184.0	4.4	17.87	na	18.6	0.05	256	13.3
414T	184.0		18.84	na				
453T	184.0		18.85	na				
454T	184.0		18.9	na				
455	184.0		19.17	na				
412	184.0	4.4	16.16	na	17.69	0.05	256	13.3
412T	174.5		21.55	na				
411	184.0	4.4	16.8	na	18.03	0.05	288	16.8
411T	174.5		22.23	na				
317	174.5		22.39	na				
318	174.5		22.44	na				
319	174.5		22.68	na				
320	174.5		23.24	na				
321	174.5		23.39	na				
424T	174.5		23.68	na				
3A	174.5		24.36	na				
19	164.25		29.05	na				
20	152.75		34.05	na				
TWR	152.75		34.1	na				
TAV	149.0		38.72	na				
BWR	146.0		40.07	na				
BKFL	146.0		40.1	na				
BASE	143.0		45.24	na				
HOSE	143.0		45.25	na				
TEST	143.0		45.26	na				

The maximum velocity is 6.27 and it occurs in the pipe between nodes 414 and 414T

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 4

Page 21  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
414 to 414T	18.60 18.6	1.101 150.0 0.0595	1E 1T	3.825 9.563	3.000 13.387	17.866 0.0		K Factor = 4.40	
414T to 453T	0.0 18.6	2.157 120.0 0.0034		0.0 0.0	3.250 0.0	18.841 0.0		Vel = 6.27	
453T to 454T	0.0 18.6	2.157 120.0 0.0034		0.0 0.0	14.000 0.0	18.852 0.0		Vel = 1.63	
454T to 455	0.0 18.6	2.157 120.0 0.0034	1E	6.153 0.0	73.000 6.153	18.899 0.0		Vel = 1.63	
455 to 321	0.0 18.6	2.157 120.0 0.0034	1E 1T	6.153 12.307	12.250 18.460	19.168 4.114		Vel = 1.63	
	0.0 18.60					23.387		K Factor = 3.85	
412 to 412T	17.69 17.69	1.101 150.0 0.0543	1E 1T	3.825 9.563	10.000 13.387	16.165 4.114		K Factor = 4.40	
412T to 318	0.0 17.69	1.394 150.0 0.0172	1T	9.523 0.0	42.250 9.523	21.548 0.0		Vel = 5.96	
	0.0 17.69					22.437		K Factor = 3.73	
411 to 411T	18.03 18.03	1.101 150.0 0.0562	1E 1T	3.825 9.563	10.000 13.387	16.800 4.114		K Factor = 4.40	
411T to 317	0.0 18.03	2.003 150.0 0.0030	1T	12.965 0.0	40.500 12.965	22.229 0.0		Vel = 6.08	
317 to 318	0.0 18.03	2.003 150.0 0.0030		0.0 0.0	15.000 0.0	22.392 0.0		Vel = 1.84	
318 to 319	17.70 35.73	2.003 150.0 0.0108	1T	12.965 0.0	9.500 12.965	22.437 0.0		Vel = 1.84	
319 to 320	0.0 35.73	2.157 120.0 0.0114	1T	12.307 0.0	37.000 12.307	22.680 0.0		Vel = 3.64	
320 to 321	0.0 35.73	2.157 120.0 0.0114	1E	6.153 0.0	6.750 6.153	23.240 0.0		Vel = 3.14	
321 to 424T	18.59 54.32	2.157 120.0 0.0247		0.0 0.0	12.000 0.0	23.387 0.0		Vel = 3.14	
				0.0	12.000	0.296		Vel = 4.77	

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 4

Page 22  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
424T	0.0	2.157	2E 12.307	15.000	23.683				
to		120.0	0.0	12.307	0.0				
3A	54.32	0.0247	0.0	27.307	0.675		Vel = 4.77		
3A	0.0	2.157	0.0	10.250	24.358				
to		120.0	0.0	0.0	4.439				
19	54.32	0.0247	0.0	10.250	0.253		Vel = 4.77		
19	0.0	4.26	1E 13.167	12.750	29.050				
to		120.0	0.0	13.167	4.981				
20	54.32	0.0009	0.0	25.917	0.023		Vel = 1.22		
20	0.0	4.26	1E 13.167	9.000	34.054				
to		120.0	1T 26.334	39.501	0.0				
TWR	54.32	0.0009	0.0	48.501	0.043		Vel = 1.22		
TWR	0.0	4.26	1Fsp 0.0	3.500	34.097				
to		120.0	0.0	0.0	4.624		* Fixed loss = 3		
TAV	54.32	0.0011	0.0	3.500	0.004		Vel = 1.22		
TAV	0.0	4.26	1B 15.8	1.000	38.725				
to		120.0	1T 26.334	51.351	1.299				
BWR	54.32	0.0009	1Eq 9.217	52.351	0.047		Vel = 1.22		
BWR	0.0	4.26	1T 26.334	3.000	40.071				
to		120.0	0.0	26.334	0.0				
BKFL	54.32	0.0009	0.0	29.334	0.026		Vel = 1.22		
BKFL	0.0	4.026	1Zac 0.0	1.000	40.097				
to		120.0	0.0	0.0	5.139		* Fixed loss = 3.84		
BASE	54.32	0.0020	0.0	1.000	0.002		Vel = 1.37		
BASE	0.0	6.16	1E 20.084	75.000	45.238				
to		140.0	1T 43.037	67.425	0.0				
HOSE	54.32	0.0001	1G 4.304	142.425	0.016		Vel = 0.58		
HOSE	0.0	6.16	0.0	50.000	45.254				
to		140.0	0.0	0.0	0.0				
TEST	54.32	0.0001	0.0	50.000	0.005		Vel = 0.58		
	0.0								
	54.32				45.259		K Factor = 8.07		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 4

Page 23  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 17.757  
D2 - System Flow : 54.323  
D2 - System Pressure : 45.259  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 54.323  
Safety Margin : 8.652





Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 5 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 4 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 324	( ) Dry	Model F1RES49
E	Elevation at Highest Outlet - 184	( ) Deluge	Size 7/16" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.9
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 70.00 Press Required - 44.819 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U  
 P Location - BRACKETT STREET

P  
 L Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 5

Page 25  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
454	184.0	4.9	13.25	na	17.84	0.05	324	12.1
453	184.0	4.9	12.96	na	17.64	0.05	324	12.1
452	184.0	4.9	12.1	na	17.04	0.05	324	12.1
451	184.0	4.9	12.73	na	17.48	0.05	324	12.1
451T	184.0		13.77	na				
452T	184.0		13.83	na				
453T	184.0		14.02	na				
454T	184.0		14.34	na				
455	184.0		17.46	na				
321	174.5		22.79	na				
424T	174.5		23.26	na				
3A	174.5		24.34	na				
19	164.25		29.18	na				
20	152.75		34.2	na				
TWR	152.75		34.27	na				
TAV	149.0		38.9	na				
BWR	146.0		40.28	na				
BKFL	146.0		40.32	na				
BASE	143.0		44.82	na				
HOSE	143.0		44.84	na				
TEST	143.0		44.85	na				

The maximum velocity is 6.15 and it occurs in the pipe between nodes 454T and 455

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 5

Page 26  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
454 to 454T	17.84	1.101 150.0	2E 1T	7.65 9.563	2.500 17.212	13.254 0.0			K Factor = 4.90	
	17.84	0.0550		0.0	19.712	1.085			Vel = 6.01	
	0.0 17.84						14.339		K Factor = 4.71	
453 to 453T	17.64	1.101 150.0	2E 1T	7.65 9.563	2.500 17.212	12.955 0.0			K Factor = 4.90	
	17.64	0.0539		0.0	19.712	1.063			Vel = 5.94	
	0.0 17.64						14.018		K Factor = 4.71	
452 to 452T	17.04	1.101 150.0	3E 2T	11.475 19.125	3.500 30.601	12.100 0.0			K Factor = 4.90	
	17.04	0.0506		0.0	34.101	1.726			Vel = 5.74	
	0.0 17.04						13.826		K Factor = 4.58	
451 to 451T	17.48	1.101 150.0	2E 1T	7.65 9.563	2.500 17.212	12.728 0.0			K Factor = 4.90	
	17.48	0.0530		0.0	19.712	1.045			Vel = 5.89	
451T to 452T	0.0	2.157 120.0		0.0 0.0	17.500 0.0	13.773 0.0				
	17.48	0.0030		0.0	17.500	0.053			Vel = 1.53	
452T to 453T	17.05	2.157 120.0		0.0 0.0	18.000 0.0	13.826 0.0				
	34.53	0.0107		0.0	18.000	0.192			Vel = 3.03	
453T to 454T	17.63	2.157 120.0		0.0 0.0	14.000 0.0	14.018 0.0				
	52.16	0.0229		0.0	14.000	0.321			Vel = 4.58	
454T to 455	17.84	2.157 120.0	1E	6.153 0.0	73.000 6.153	14.339 0.0				
	70.0	0.0395		0.0	79.153	3.124			Vel = 6.15	
455 to 321	0.0	2.157 120.0	1E 1T	6.153 12.307	12.250 18.460	17.463 4.114				
	70.0	0.0395		0.0	30.710	1.213			Vel = 6.15	
321 to 424T	0.0	2.157 120.0		0.0 0.0	12.000 0.0	22.790 0.0				
	70.0	0.0394		0.0	12.000	0.473			Vel = 6.15	
424T to 3A	0.0	2.157 120.0	2E	12.307 0.0	15.000 12.307	23.263 0.0				
	70.0	0.0395		0.0	27.307	1.078			Vel = 6.15	
3A to 19	0.0	2.157 120.0		0.0 0.0	10.250 0.0	24.341 4.439				
	70.0	0.0395		0.0	10.250	0.405			Vel = 6.15	
19 to 20	0.0	4.26 120.0	1E	13.167 0.0	12.750 13.167	29.185 4.981				
	70.0	0.0014		0.0	25.917	0.036			Vel = 1.58	

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 5

Page 27  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
20 to TWR	0.0 70.0	4.26 120.0 0.0014	1E 13.167 1T 26.334	9.000 39.501 48.501	34.202 0.0 0.070		Vel = 1.58		
TWR to TAV	0.0 70.0	4.26 120.0 0.0014	1Fsp 0.0 0.0	3.500 0.0 3.500	34.272 4.624 0.005		* Fixed loss = 3 Vel = 1.58		
TAV to BWR	0.0 70.0	4.26 120.0 0.0015	1B 15.8 1T 26.334 1Eq 9.217	1.000 51.351 52.351	38.901 1.299 0.076		Vel = 1.58		
BWR to BKFL	0.0 70.0	4.26 120.0 0.0014	1T 26.334 0.0	3.000 26.334 29.334	40.276 0.0 0.042		Vel = 1.58		
BKFL to BASE	0.0 70.0	4.026 120.0 0.0020	1Zac 0.0 0.0	1.000 0.0 1.000	40.318 4.499 0.002		* Fixed loss = 3.2 Vel = 1.76		
BASE to HOSE	0.0 70.0	6.16 140.0 0.0002	1E 20.084 1T 43.037 1G 4.304	75.000 67.425 142.425	44.819 0.0 0.025		Vel = 0.75		
HOSE to TEST	0.0 70.0	6.16 140.0 0.0002	0.0 0.0	50.000 0.0 50.000	44.844 0.0 0.010		Vel = 0.75		
	0.0 70.00				44.854		K Factor = 10.45		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 5

Page 28  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 17.757  
D2 - System Flow : 70.001  
D2 - System Pressure : 44.854  
Hose ( Demand ) :  
D3 - System Demand : 70.001  
Safety Margin : 9.005



Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 6 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 4 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 256	( ) Dry	Model F1RES44
E	Elevation at Highest Outlet - 184	( ) Deluge	Size 3/8" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.4
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 70.51 Press Required - 48.272 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143		

U  
 P Location - BRACKETT STREET

P  
 L Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 6

Page 30  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
424	184.0	4.4	20.91	na	20.12	0.05	256	13.3
423	184.0	4.4	15.85	na	17.52	0.05	256	13.3
421	184.0	4.4	13.3	na	16.05	0.05	256	13.3
422	184.0	4.4	14.64	na	16.83	0.05	256	13.3
422A	174.5		19.8	na				
422B	174.5		20.77	na				
423T	174.5		21.74	na				
317	174.5		24.37	na				
318	174.5		24.68	na				
319	174.5		25.14	na				
320	174.5		26.2	na				
321	174.5		26.47	na				
424T	174.5		26.73	na				
3A	174.5		27.83	na				
19	164.25		32.67	na				
20	152.75		37.69	na				
TWR	152.75		37.76	na				
TAV	149.0		42.39	na				
BWR	146.0		43.77	na				
BKFL	146.0		43.81	na				
BASE	143.0		48.27	na				
HOSE	143.0		48.3	na				
TEST	143.0		48.31	na				

The maximum velocity is 8.06 and it occurs in the pipe between nodes 423T and 317

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 6

Page 31  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
424 to 424T	20.12 20.12	1.101 150.0 0.0688	1E 1T	3.825 9.563 0.0	11.500 13.387 24.887	20.906 4.114 1.713		K Factor = 4.40	
	0.0 20.12					26.733		K Factor = 3.89	
423 to 423T	17.52 17.52	1.101 150.0 0.0533	2E 1T	7.65 9.563 0.0	16.250 17.212 33.462	15.848 4.114 1.782		K Factor = 4.40	
	0.0 17.52					21.744		K Factor = 3.76	
421 to 422A	16.05 16.05	1.101 150.0 0.0453	3E 2T	11.475 19.125 0.0	22.000 30.601 52.601	13.300 4.114 2.382		K Factor = 4.40	
	0.0 16.05					19.796		K Factor = 3.61	
422 to 422A	16.83 16.83	1.101 150.0 0.0495	2E	7.65 0.0 0.0	13.500 7.650 21.150	14.635 4.114 1.047		K Factor = 4.40	
422A to 422B	16.05 32.88	1.394 150.0 0.0541	1T	9.523 0.0 0.0	8.500 9.523 18.023	19.796 0.0 0.975		Vel = 6.91	
422B to 423T	0.0 32.88	1.394 150.0 0.0541		0.0 0.0 0.0	18.000 0.0 18.000	20.771 0.0 0.973		Vel = 6.91	
423T to 317	17.52 50.4	1.598 150.0 0.0613	1T	11.656 0.0 0.0	31.250 11.656 42.906	21.744 0.0 2.630		Vel = 8.06	
317 to 318	0.0 50.4	2.003 150.0 0.0204		0.0 0.0 0.0	15.000 0.0 15.000	24.374 0.0 0.306		Vel = 5.13	
318 to 319	0.0 50.4	2.003 150.0 0.0204	1T	12.965 0.0 0.0	9.500 12.965 22.465	24.680 0.0 0.458		Vel = 5.13	
319 to 320	0.0 50.4	2.157 120.0 0.0215	1T	12.307 0.0 0.0	37.000 12.307 49.307	25.138 0.0 1.060		Vel = 4.43	
320 to 321	0.0 50.4	2.157 120.0 0.0215	1E	6.153 0.0 0.0	6.750 6.153 12.903	26.198 0.0 0.277		Vel = 4.43	
321 to 424T	0.0 50.4	2.157 120.0 0.0215		0.0 0.0 0.0	12.000 0.0 12.000	26.475 0.0 0.258		Vel = 4.43	
424T to 3A	20.11 70.51	2.157 120.0 0.0400	2E	12.307 0.0 0.0	15.000 12.307 27.307	26.733 0.0 1.092		Vel = 6.19	



Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 6

Page 32  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
3A	0.0	2.157		10.250	27.825				
to		120.0		0.0	4.439				
19	70.51	0.0401		10.250	0.411		Vel = 6.19		
19	0.0	4.26	1E 13.167	12.750	32.675				
to		120.0		0.0	4.981				
20	70.51	0.0014		25.917	0.037		Vel = 1.59		
20	0.0	4.26	1E 13.167	9.000	37.693				
to		120.0	1T 26.334	39.501	0.0				
TWR	70.51	0.0014		48.501	0.070		Vel = 1.59		
TWR	0.0	4.26	1Fsp 0.0	3.500	37.763				
to		120.0		0.0	4.624		* Fixed loss = 3		
TAV	70.51	0.0017		3.500	0.006		Vel = 1.59		
TAV	0.0	4.26	1B 15.8	1.000	42.393				
to		120.0	1T 26.334	51.351	1.299				
BWR	70.51	0.0015	1Eq 9.217	52.351	0.076		Vel = 1.59		
BWR	0.0	4.26	1T 26.334	3.000	43.768				
to		120.0		0.0	26.334	0.0			
BKFL	70.51	0.0015		29.334	0.043		Vel = 1.59		
BKFL	0.0	4.026	1Zac 0.0	1.000	43.811				
to		120.0		0.0	4.459		* Fixed loss = 3.16		
BASE	70.51	0.0020		1.000	0.002		Vel = 1.78		
BASE	0.0	6.16	1E 20.084	75.000	48.272				
to		140.0	1T 43.037	67.425	0.0				
HOSE	70.51	0.0002	1G 4.304	142.425	0.026		Vel = 0.76		
HOSE	0.0	6.16		50.000	48.298				
to		140.0		0.0	0.0				
TEST	70.51	0.0002		50.000	0.009		Vel = 0.76		
	0.0								
	70.51				48.307		K Factor = 10.14		


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 6

Page 33  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 17.757  
D2 - System Flow : 70.514  
D2 - System Pressure : 48.307  
Hose ( Demand ) :  
D3 - System Demand : 70.514  
Safety Margin : 5.549



Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 7 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation - 4 Heads	System Type	Sprinkler/Nozzle
	Density - .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler - 256	( ) Dry	Model F1RES49
E	Elevation at Highest Outlet - 174.500	( ) Deluge	Size 7/16" x 1/2"
S	Hose Allowance - Inside - 0	( ) Preaction	K-Factor 4.9
I	Rack Sprinkler Allowance - 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 0		

N Note

Calculation Flow Required - 54.31 Press Required - 39.226 AT BASE  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U  
 P Location - BRACKETT STREET

P  
 L Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	%	Palletized % Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

O C  
 R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G  
 E Horizontal Barriers Provided:

# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 7

Page 35  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
ARM1	174.5	4.9	8.39	na	14.19	0.05	256	7.0
303	174.5	4.9	8.19	na	14.02	0.05	256	7.0
304	174.5		9.02	na				
401A	174.5		12.75	na				
ARM2	174.5	4.9	7.18	na	13.13	0.05	256	7.0
301	174.5	4.9	7.0	na	12.96	0.05	256	7.0
302	174.5		7.69	na				
302T	174.5		13.68	na				
403A	174.5		13.69	na				
305	174.5		13.75	na				
306	174.5		14.38	na				
319	174.5		15.84	na				
320	174.5		17.06	na				
321	174.5		17.38	na				
424T	174.5		17.67	na				
3A	174.5		18.35	na				
19	164.25		23.04	na				
20	152.75		28.04	na				
TWR	152.75		28.09	na				
TAV	149.0		32.71	na				
BWR	146.0		34.06	na				
BKFL	146.0		34.09	na				
BASE	143.0		39.23	na				
HOSE	143.0		39.24	na				
TEST	143.0		39.25	na				

The maximum velocity is 9.51 and it occurs in the pipe between nodes 304 and 401A

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 7

Page 36  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
ARM1 to 304	14.19 14.19	1.101 150.0 0.0361	1E 3.825 1T 9.563 0.0	4.000 13.387 17.387	8.392 0.0 0.627		K Factor = 4.90 Vel = 4.78		
	0.0 14.19				9.019		K Factor = 4.73		
303 to 304	14.02 14.02	1.101 150.0 0.0353	2E 7.65 0.0 0.0	16.000 7.650 23.650	8.185 0.0 0.834		K Factor = 4.90 Vel = 4.72		
304 to 401A	14.19 28.21	1.101 150.0 0.1286	0.0 0.0 0.0	29.000 0.0 29.000	9.019 0.0 3.729		Vel = 9.51		
401A to 305	0.0 28.21	1.394 150.0 0.0408	1T 9.523 0.0 0.0	15.000 9.523 24.523	12.748 0.0 1.000		Vel = 5.93		
	0.0 28.21				13.748		K Factor = 7.61		
ARM2 to 302	13.13 13.13	1.101 150.0 0.0312	1E 3.825 1T 9.563 0.0	3.000 13.387 16.387	7.179 0.0 0.512		K Factor = 4.90 Vel = 4.42		
	0.0 13.13				7.691		K Factor = 4.73		
301 to 302	12.96 12.96	1.101 150.0 0.0305	2E 7.65 0.0 0.0	15.000 7.650 22.650	7.000 0.0 0.691		K Factor = 4.90 Vel = 4.37		
302 to 302T	13.13 26.09	1.101 150.0 0.1113	1T 9.563 0.0 0.0	44.250 9.562 53.812	7.691 0.0 5.989		Vel = 8.79		
302T to 403A	0.0 26.09	2.003 150.0 0.0060	0.0 0.0 0.0	1.000 0.0 1.000	13.680 0.0 0.006		Vel = 2.66		
403A to 305	0.0 26.09	2.003 150.0 0.0060	0.0 0.0 0.0	10.250 0.0 10.250	13.686 0.0 0.062		Vel = 2.66		
305 to 306	28.22 54.31	2.003 150.0 0.0234	1T 12.965 0.0 0.0	14.250 12.965 27.215	13.748 0.0 0.637		Vel = 5.53		
306 to 319	0.0 54.31	2.157 120.0 0.0247	0.0 0.0 0.0	59.000 0.0 59.000	14.385 0.0 1.456		Vel = 4.77		
319 to 320	0.0 54.31	2.157 120.0 0.0247	1T 12.307 0.0 0.0	37.000 12.307 49.307	15.841 0.0 1.217		Vel = 4.77		
320 to 321	0.0 54.31	2.157 120.0 0.0246	1E 6.153 0.0 0.0	6.750 6.153 12.903	17.058 0.0 0.318		Vel = 4.77		

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 7

Page 37  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
321 to 424T	0.0 54.31	2.157 120.0 0.0247		0.0 0.0 12.000	12.000 0.0 0.296	17.376 0.0		Vel = 4.77	
424T to 3A	0.0 54.31	2.157 120.0 0.0247	2E	12.307 0.0 27.307	15.000 12.307 0.674	17.672 0.0		Vel = 4.77	
3A to 19	0.0 54.31	2.157 120.0 0.0247		0.0 0.0 10.250	10.250 0.0 0.253	18.346 4.439		Vel = 4.77	
19 to 20	0.0 54.31	4.26 120.0 0.0009	1E	13.167 0.0 25.917	12.750 13.167 0.023	23.038 4.981		Vel = 1.22	
20 to TWR	0.0 54.31	4.26 120.0 0.0009	1E 1T	13.167 26.334 0.0	9.000 39.501 48.501	28.042 0.0 0.044		Vel = 1.22	
TWR to TAV	0.0 54.31	4.26 120.0 0.0009	1Fsp	0.0 0.0 0.0	3.500 0.0 3.500	28.086 4.624 0.003		* Fixed loss = 3 Vel = 1.22	
TAV to BWR	0.0 54.31	4.26 120.0 0.0009	1B 1T 1Eq	15.8 26.334 9.217	1.000 51.351 52.351	32.713 1.299 0.047		Vel = 1.22	
BWR to BKFL	0.0 54.31	4.26 120.0 0.0009	1T	26.334 0.0 29.334	3.000 26.334 29.334	34.059 0.0 0.027		Vel = 1.22	
BKFL to BASE	0.0 54.31	4.026 120.0 0.0010	1Zac	0.0 0.0 0.0	1.000 0.0 1.000	34.086 5.139 0.001		* Fixed loss = 3.84 Vel = 1.37	
BASE to HOSE	0.0 54.31	6.16 140.0 0.0001	1E 1T 1G	20.084 43.037 4.304	75.000 67.425 142.425	39.226 0.0 0.016		Vel = 0.58	
HOSE to TEST	0.0 54.31	6.16 140.0 0.0001		0.0 0.0 0.0	50.000 0.0 50.000	39.242 0.0 0.006		Vel = 0.58	
	0.0 54.31					39.248		K Factor = 8.67	


# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 7

Page 38  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 13.643  
D2 - System Flow : 54.307  
D2 - System Pressure : 39.248  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 54.307  
Safety Margin : 14.664



Hydraulic Design Information Sheet

Name - West End Apartments Wet System Area 8 Date - 05/21/14  
 Location - 44 Pine Street Portland, Maine  
 Building - NEW System No. - 1 Wet  
 Contractor - SPRINKLER SYSTEMS INC. Contract No. - 13-058  
 Calculated By - CDS Drawing No. - 1-4 OF 4  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - VARIES  
 Occupancy - Residential

S ( ) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other NFPA 13R  
 T Specific Ruling

Made By Date

M	Area of Sprinkler Operation	- 4 Heads	System Type	Sprinkler/Nozzle
	Density	- .05	(x) Wet	Make RELIABLE
D	Area Per Sprinkler	- 324	( ) Dry	Model F1RES49
E	Elevation at Highest Outlet	- 174.500	( ) Deluge	Size 7/16" x 1/2"
S	Hose Allowance - Inside	- 0	( ) Preaction	K-Factor 4.9
I	Rack Sprinkler Allowance	- 0	( ) Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside	- 0		

N Note

Calculation Flow Required - 69.18 Press Required - 43.212 AT BASE  
 Summary C-Factor Used: 150 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04/25/14		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 54	@ Press -	
R	Residual Press - 40	Elev. -	Well
	Flow - 838		Proof Flow
S	Elevation - 143.0'		

U Location - BRACKETT STREET

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:



# Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 8

Page 40  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
ARM1	174.5	4.9	12.6	na	17.39	0.05	324	12.1
315	174.5	4.9	12.66	na	17.44	0.05	324	12.1
408	174.5		13.33	na				
311	174.5	4.9	12.1	na	17.04	0.05	324	12.1
406A	174.5		12.88	na				
312	174.5	4.9	12.47	na	17.3	0.05	324	12.1
313	174.5		13.02	na				
314	174.5		13.41	na				
316	174.5		13.48	na				
411T	174.5		15.45	na				
317	174.5		17.41	na				
318	174.5		17.96	na				
319	174.5		18.79	na				
320	174.5		20.69	na				
321	174.5		21.19	na				
424T	174.5		21.65	na				
3A	174.5		22.71	na				
19	164.25		27.54	na				
20	152.75		32.56	na				
TWR	152.75		32.63	na				
TAV	149.0		37.26	na				
BWR	146.0		38.63	na				
BKFL	146.0		38.67	na				
BASE	143.0		43.21	na				
HOSE	143.0		43.24	na				
TEST	143.0		43.25	na				

The maximum velocity is 8.28 and it occurs in the pipe between nodes 314 and 316

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 8

Page 41  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
ARM1 to 314	17.40 17.4	1.101 150.0 0.0526	1E 1T	3.825 9.563 0.0	2.000 13.387 15.387	12.602 0.0 0.809			K Factor = 4.90	
	0.0 17.40						13.411		K Factor = 4.75	
315 to 408	17.44 17.44	1.101 150.0 0.0528	2E	7.65 0.0 0.0	5.000 7.650 12.650	12.662 0.0 0.668			K Factor = 4.90	
									Vel = 5.88	
408 to 316	0.0 17.44	1.101 150.0 0.0531		0.0 0.0 0.0	2.750 0.0 2.750	13.330 0.0 0.146				Vel = 5.88
	0.0 17.44						13.476		K Factor = 4.75	
311 to 406A	17.04 17.04	1.101 150.0 0.0506	1E 1T	3.825 9.563 0.0	2.000 13.387 15.387	12.100 0.0 0.779			K Factor = 4.90	
									Vel = 5.74	
406A to 313	0.0 17.04	1.394 150.0 0.0160		0.0 0.0 0.0	8.750 0.0 8.750	12.879 0.0 0.140				Vel = 3.58
	0.0 17.04						13.019		K Factor = 4.72	
312 to 313	17.30 17.3	1.101 150.0 0.0520	2E	7.65 0.0 0.0	3.000 7.650 10.650	12.465 0.0 0.554			K Factor = 4.90	
									Vel = 5.83	
313 to 314	17.04 34.34	1.598 150.0 0.0302		0.0 0.0 0.0	13.000 0.0 13.000	13.019 0.0 0.392				Vel = 5.49
314 to 316	17.40 51.74	1.598 150.0 0.0650		0.0 0.0 0.0	1.000 0.0 1.000	13.411 0.0 0.065				Vel = 8.28
316 to 411T	17.44 69.18	2.003 150.0 0.0366		0.0 0.0 0.0	54.000 0.0 54.000	13.476 0.0 1.979				Vel = 7.04
411T to 317	0.0 69.18	2.003 150.0 0.0366	1T	12.965 0.0 0.0	40.500 12.965 53.465	15.455 0.0 1.959				Vel = 7.04
317 to 318	0.0 69.18	2.003 150.0 0.0367		0.0 0.0 0.0	15.000 0.0 15.000	17.414 0.0 0.550				Vel = 7.04
318 to 319	0.0 69.18	2.003 150.0 0.0367	1T	12.965 0.0 0.0	9.500 12.965 22.465	17.964 0.0 0.824				Vel = 7.04
319 to 320	0.0 69.18	2.157 120.0 0.0386	1T	12.307 0.0 0.0	37.000 12.307 49.307	18.788 0.0 1.903				Vel = 6.07

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 8

Page 42  
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
320 to 321	0.0 69.18	2.157 120.0 0.0387	1E 0.0 0.0	6.153 0.0 12.903	6.750 6.153 0.499	20.691 0.0 0.499		Vel = 6.07	
321 to 424T	0.0 69.18	2.157 120.0 0.0386	0.0 0.0 0.0	12.000 0.0 12.000	21.190 0.0 0.463			Vel = 6.07	
424T to 3A	0.0 69.18	2.157 120.0 0.0386	2E 0.0 0.0	12.307 0.0 27.307	15.000 12.307 27.307	21.653 0.0 1.054		Vel = 6.07	
3A to 19	0.0 69.18	2.157 120.0 0.0386	0.0 0.0 0.0	10.250 0.0 10.250	22.707 0.0 10.250	22.707 4.439 0.396		Vel = 6.07	
19 to 20	0.0 69.18	4.26 120.0 0.0014	1E 0.0 0.0	13.167 0.0 25.917	12.750 13.167 25.917	27.542 4.981 0.036		Vel = 1.56	
20 to TWR	0.0 69.18	4.26 120.0 0.0014	1E 1T 0.0	13.167 26.334 0.0	9.000 39.501 48.501	32.559 0.0 0.068		Vel = 1.56	
TWR to TAV	0.0 69.18	4.26 120.0 0.0014	1Fsp 0.0 0.0	0.0 0.0 3.500	3.500 0.0 3.500	32.627 4.624 0.005		* Fixed loss = 3 Vel = 1.56	
TAV to BWR	0.0 69.18	4.26 120.0 0.0014	1B 1T 1Eq	15.8 26.334 9.217	1.000 51.351 52.351	37.256 1.299 0.074		Vel = 1.56	
BWR to BKFL	0.0 69.18	4.26 120.0 0.0014	1T 0.0 0.0	26.334 0.0 29.334	3.000 26.334 29.334	38.629 0.0 0.041		Vel = 1.56	
BKFL to BASE	0.0 69.18	4.026 120.0 0.0030	1Zac 0.0 0.0	0.0 0.0 1.000	1.000 0.0 1.000	38.670 4.539 0.003		* Fixed loss = 3.24 Vel = 1.74	
BASE to HOSE	0.0 69.18	6.16 140.0 0.0002	1E 1T 1G	20.084 43.037 4.304	75.000 67.425 142.425	43.212 0.0 0.025		Vel = 0.74	
HOSE to TEST	0.0 69.18	6.16 140.0 0.0002	0.0 0.0 0.0	0.0 0.0 50.000	50.000 0.0 50.000	43.237 0.0 0.008		Vel = 0.74	
	0.0 69.18					43.245		K Factor = 10.52	

# Water Supply Curve (C)

SPRINKLER SYSTEMS INC.  
WEST END APTS. WET SYSTEM AREA 8

Page 43  
Date

City Water Supply:  
C1 - Static Pressure : 54  
C2 - Residual Pressure: 40  
C2 - Residual Flow : 838

Demand:  
D1 - Elevation : 13.643  
D2 - System Flow : 69.176  
D2 - System Pressure : 43.245  
Hose ( Demand ) :  
D3 - System Demand : 69.176  
Safety Margin : 10.616

