
Fwd: 1 Joy PI to PB Hearing- report being finalized today/tomorrow AM

1 message

Jean Fraser <jf@portlandmaine.gov>
To: "Fraser, Jean" <jf@portlandmaine.gov>

Fri, Sep 22, 2017 at 11:20 AM

From: **Deb Andrews** <dga@portlandmaine.gov>
Date: Fri, Sep 22, 2017 at 10:41 AM
Subject: Re: 1 Joy PI to PB Hearing- report being finalized today/tomorrow AM
To: Jean Fraser <jf@portlandmaine.gov>

I have reviewed the final site plan revisions for One Joy Place and find that they are generally consistent with the plans approved by the Historic Preservation Board. The one element that I question in terms of its compatibility with the development's context is the bollard specification, which calls for a square concrete bollard. I recommend a dark metal bollard as it would be more visually recessive and consistent with other metal public infrastructure fixtures in the West End Historic District. A bollard similar to that installed at Williston West might be considered.

Deb

--

Deb Andrews
Historic Preservation Program Manager
[City of Portland](#)
[389 Congress Street](#)
Portland, Maine 04101
[\(207\) 874-8726](#)