

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
CLOUTIER FRANCIS R

Located at
75 GRAY ST

PERMIT ID: 2017-00636 **ISSUE DATE:** 06/01/2017 **CBL:** 045 F017001

has permission to **Convert three dwelling units to three residential condominium units** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
Three residential condominium units

Building Inspections

Fire Department

Classification:
Apartment Building
ENTIRE
NFPA 101 CH 31

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final Inspection
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00636	Date Applied For: 05/02/2017	CBL: 045 F017001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Three residential condominium units	Proposed Project Description: Convert three dwelling units to three residential condominium units			
Dept: Historic Status: Approved w/Conditions Reviewer: Deborah Andrews Approval Date: 05/18/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Any exterior alterations associated with the change in use require and approval by Historic Preservation staff.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 05/08/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Upon issuance of the Certificates of Occupancy, this property shall remain a three residential condominium units. Any change of use shall require a separate permit application for review and approval. 2) This is not approving any construction. Any proposed construction or alterations shall require separate review and approval. 3) PLEASE NOTE: Under the City's Condominium Conversion regulations, if a tenant makes a decision not to purchase their unit and also decides not to remain in the building after their notification, that tenant has the right to move without penalty. If that protected tenant is under the 80% low/moderated income limit guidelines, there is still a requirement on the owner/developer to pay that tenant relocation payments as stated in the ordinance prior to vacating the unit. That tenant has not lost any rights under this ordinance by making a choice to move and vacate their unit after notification.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 05/16/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This permit recognizes a pre-existing use and does not require or certify compliance with the City's current building code. The inspection performed will be done pursuant to the City's Minimum Standards for Housing, The Housing Code. All violations shall be corrected prior to the final inspection and the issuance of the Certificate of Occupancy. 2) This is a Change of Use ONLY permit. It does NOT authorize any construction activities. 3) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection. 4) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery. 5) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Jason Grant Approval Date: 05/31/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions:				

- 1) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.
 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 2) City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be non-ionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
 1. Inside all sleeping rooms.
 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.