

# ELECTRICAL PERMIT City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 9-29-10  
Permit # 2010-4672  
CBL# 045 F017

LOCATION: 25 Gray #1 METER MAKE & # \_\_\_\_\_  
CMP ACCOUNT # \_\_\_\_\_ OWNER Frank Cloutier  
TENANT \_\_\_\_\_ PHONE # \_\_\_\_\_

045 - F 017 001

							TOTAL EACH FEE	
OUTLETS	25	Receptacles	10	Switches	3	Smoke Detector		.20
FIXTURES	15	Incandescent		Fluorescent	3	Strips		.20
SERVICES		Overhead		Underground		TTL AMPS <800		15.00
		Overhead		Underground		>800		25.00
Temporary Service		Overhead		Underground		TTL AMPS		25.00
								25.00
METERS		(number of)						1.00
MOTORS		(number of)						2.00
RESID/COM		Electric units						1.00
HEATING		oil/gas units		Interior		Exterior		5.00
APPLIANCES	1	Ranges		Cook Tops		Wall Ovens		2.00
		Insta-Hot		Water heaters		Fans		2.00
	1	Dryers	1	Disposals	1	Dishwasher		2.00
		Compactors		Spa		Washing Machine		2.00
		Others (denote)						2.00
MISC. (number of)		Air Cond/win						3.00
		Air Cond/cent				Pools		10.00
		HVAC		EMS		Thermostat		5.00
		Signs						10.00
		Alarms/res						5.00
		Alarms/com						15.00
		Heavy Duty(CRKT)						2.00
		Circus/Carnv						25.00
		Alterations						5.00
		Fire Repairs						15.00
		E Lights						10.00
		E Generators						20.00
PANELS		Service	1	Remote		Main		4.00
TRANSFORMER		0-25 Kva						5.00
		25-200 Kva						8.00
		Over 200 Kva						10.00
TOTAL AMOUNT DUE								
MINIMUM FEE/COMMERCIAL							55.00	
MINIMUM FEE							45.00	35.00

**RECEIVED**  
SEP 29 2010  
Dept. of Building Inspection  
City of Portland Maine

CONTRACTORS NAME Chuck Daighe MASTER LIC. # 17036  
ADDRESS 264 Falmouth Pk Way LIMITED LIC. # \_\_\_\_\_  
TELEPHONE 838-3814

SIGNATURE OF CONTRACTOR \_\_\_\_\_

**ELECTRICAL INSTALLATIONS**

Permit Number \_\_\_\_\_

Location \_\_\_\_\_

Owner \_\_\_\_\_

Date of Permit \_\_\_\_\_

Final Inspection \_\_\_\_\_

By Inspector \_\_\_\_\_

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_  
 / Service called in \_\_\_\_\_  
 Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:	REMARKS:
10/22/2010	Recessed cans missing, 20 AMP circuit in Dining Room, CRIPPLE THE BATHROOM Fan over
	The Shower - Need to inspect before close in .... BKL (with 1x Mount)
2/4/2011	3rd Floor OK to close in BKL
1/30/2012	Shower been closed - BKL

*PS TP*  
 ELECTRICAL PERMITS  
 DIVISION OF BUILDING  
 1000 MARKET STREET, SUITE 1000  
 SAN FRANCISCO, CA 94102  
 (415) 398-3300