

Conditions Section:

Add New Condition From Default List

Add New Condition

Delete Condition

Condition Date: 11/4/2015

Status: Final

Notes:

Window replacements are to of wood, with 2/2 simulated divided lights (SDL,) and 5/8" muntins with a putty glazed profile. Window sills to be 2" thick historic profile, and screens are to be half screens.

Condition Date: 11/4/2015

Status: Final

Notes:

Final design for handrails at front steps is to be reviewed and approved by HP staff prior to construction.

Condition Date: 11/4/2015

Status: Final

Notes:

Final choice for front gable siding is to be reviewed and approved by HP staff prior to construction.

Condition Date: 11/4/2015

Status: Final

Notes:

All exterior trim is to be painted, after being retained, repaired, or replaced with matching components.

Condition Date: 11/4/2015

Status: Final

Notes:

Painted or solid stained wood clapboard siding to replace existing vinyl is to be installed with the smooth side facing out.



Approved for Historic Preservation Certificate of Appropriateness

11/04/15

Date: _____

Compliance Date: _____

Sign Off: _____

Condition Type _____

Compliance Needed By: _____

Compliance Date: _____

Sign Off: _____

Condition Type _____

Compliance Needed By: _____

Compliance Date: _____

Sign Off: _____

Condition Type _____

Compliance Needed By: _____

Compliance Date: _____

Sign Off: _____



Approved for Historic Preservation
Certificate of Appropriateness

11/04/15

Date: _____

