
202 Spring St

fantasticfarm <fantasticfarm@myfairpoint.net>
To: Glenn Harmon <gharmon@portlandmaine.gov>

Tue, Jan 23, 2018 at 12:29 PM

Hello Glenn,

I am writing to answer the questions you sent me regarding sheets C1 and A2 of the plans for a proposed portico at [202 Spring St](#).

The soffit material will be 3/4" pine at the perimeter and 1/2" plywood in the interior to create a double sunken panel. Yes, the existing trim will be cut back to the sheathing. The downspout, which originally came down in the corner and followed the stairs to empty at their end on the driveway, will instead turn at the portico and follow its roofline past the window to the corner of the building where it will turn down, continue to grade and empty onto the driveway. I intend to continue the rubber roofing itself up the face of the building for 6 to 8" and lap the siding back over it. The bracket is a custom item which I will make from glued and screwed 1 and 2 x softwood.

If you have any further questions I will be happy to answer them.

Regards

Ezra Boucher
h.207 636 7274
c.207 210 7214

From: Glenn Harmon
Sent: Monday, January 22, 2018 1:59 PM
To: fantasticfarm@myfairpoint.net
Subject: Fwd: 202 Spring St

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.