

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> STEPHENS CLARK B		<b>Inspector</b> Peter Merrow	<b>Inspection Date</b> 12/02/2005
<b>Location</b> 198 SPRING ST	<b>CBL</b> 045 F026001	<b>Status</b> Re-Inspect 10 Days	<b>Inspection Type</b> Complaint-Social Services/Genera

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-116.5	Interior	1	4		
<b>Violation:</b> Fire Protection					
<b>Notes:</b> No Hard wired Some detectors					

---

**Comments:** Fail, no hard wired smokes