



. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : 243 STATE STREET HC1
Building : 243 STATE STREET
Location : PORTLAND, MAINE 04101
System : #1 AREA #1
Contract :
Data File : 243 State Street HC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 243 STATE STREET Date - 7/12/11
Location - PORTLAND, MAINE 04101
Building - 243 STATE STREET System No. - #1 AREA #1
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MICHAEL NOBLIT Drawing No. - FP-2
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - APARTMENTS

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 14.5 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 14 x 14 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 39'-4"Feet Size 1/2" K-Factor 4.2
G Note: Temperature Rating 155
N

Calculation Gpm Required 32.351 Psi Required 48.696 At Test
Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 50 Cap.
T Time of Test - @ Psi 50 Elev.
E Static (Psi) - Elev.
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
243 STATE STREET HC1


Page 2
Date 7/12/11

Pump Data:

P1 - Pump Churn Pressure : 55
 P2 - Pump Rated Pressure : 50
 P2 - Pump Rated Flow : 50
 P3 - Pump Pressure @ Max Flow : 32.5
 P3 - Pump Max Flow : 75

Demand:

D1 - Elevation : 17.034
 D2 - System Flow : 32.3506
 D2 - System Pressure : 48.696
 Hose (Adj City) : _____
 Hose (Demand) : _____
 D3 - System Demand : 32.3506
 Safety Margin : 5.123



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
243 STATE STREET HC1

Page 3
Date 7/12/11

Fitting Legend																					
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
243 STATE STREET HC1

Page 4
Date 7/12/11

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	39.33	4.2	15.17	na	16.36	0.05	0.001	14.5
102	39.33	4.2	14.5	na	15.99	0.05	0.001	14.5
9	39.33		14.97	na				
8	39.33		15.66	na				
7	39.33		21.55	na				
6	39.33		22.1	na				
5	29.33		27.77	na				
4	29.33		30.19	na				
3	7.66		41.88	na				
2	7.66		44.07	na				
1	1.0		48.18	na				
TEST	0.0		48.7	na				

The maximum velocity is 12.01 and it occurs in the pipe between nodes 8 and 7

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
243 STATE STREET HC1

Page 5
Date 7/12/11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101 to 8	16.36	1.049 120	1T 5.0 0.0	0.500 5.000	15.168 0.0			K Factor = 4.20	
	16.36	0.0898	0.0	5.500	0.494			Vel = 6.07	
	0.0								
	16.36				15.662			K Factor = 4.13	
102 to 9	15.99	1.049 120	1T 5.0 0.0	0.500 5.000	14.500 0.0			K Factor = 4.20	
	15.99	0.0860	0.0	5.500	0.473			Vel = 5.94	
9 to 8	0.0	1.049 120	0.0 0.0	8.000 0.0	14.973 0.0				
	15.99	0.0861	0.0	8.000	0.689			Vel = 5.94	
8 to 7	16.36	1.049 120	1E 2.0 1T 5.0	11.583 7.000	15.662 0.0				
	32.35	0.3167	0.0	18.583	5.886			Vel = 12.01	
7 to 6	0.0	1.38 120	1T 6.0 0.0	0.660 6.000	21.548 0.0				
	32.35	0.0833	0.0	6.660	0.555			Vel = 6.94	
6 to 5	0.0	1.38 120	1T 6.0 0.0	10.000 6.000	22.103 4.331				
	32.35	0.0833	0.0	16.000	1.333			Vel = 6.94	
5 to 4	0.0	1.38 120	2E 6.0 1T 6.0	17.083 12.000	27.767 0.0				
	32.35	0.0833	0.0	29.083	2.423			Vel = 6.94	
4 to 3	0.0	1.38 120	1T 6.0 0.0	21.660 6.000	30.190 9.385				
	32.35	0.0833	0.0	27.660	2.305			Vel = 6.94	
3 to 2	0.0	1.38 120	1T 6.0 0.0	20.330 6.000	41.880 0.0				
	32.35	0.0833	0.0	26.330	2.194			Vel = 6.94	
2 to 1	0.0	1.38 120	1S 7.0 0.0	7.660 7.000	44.074 2.884				
	32.35	0.0834	0.0	14.660	1.222			Vel = 6.94	
1 to TEST	0.0	1.38 120	0.0 0.0	1.000 0.0	48.180 0.433				
	32.35	0.0830	0.0	1.000	0.083			Vel = 6.94	
	0.0								
	32.35				48.696			K Factor = 4.64	