



**. . . Fire Protection by Computer Design**

FREEDOM FIRE PROTECTION INC.  
209 QUAKER RIDGE ROAD  
CASCO, MAINE 04015  
207-627-4109

Job Name : 243 STATE STREET HC2  
Building : 243 STATE STREET  
Location : PORTLAND, MAINE 04101  
System : #1 AREA #2  
Contract :  
Data File : 243 State Street HC2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 243 STATE STREET Date - 7/12/11  
Location - PORTLAND, MAINE 04101  
Building - 243 STATE STREET System No. - #1 AREA #2  
Contractor - FREEDOM FIRE PROTECTION Contract No. -  
Calculated By - MICHAEL NOBLIT Drawing No. - FP-2  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 10'-0"  
OCCUPANCY - APARTMENTS

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 ( )4 (X)3  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 16 Gpm System Type  
Listed Pres. at Start Point - 14.5 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 16 x 16 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - 0 Gpm Make TYCO Model LFII  
I Elevation at Highest Outlet - 29'-4"Feet Size 1/2" K-Factor 4.2  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 49.344 Psi Required 44.081 At Test  
Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - Rated Cap. 50 Cap.  
T Time of Test - @ Psi 50 Elev.  
E Static (Psi) - Elev.  
R Residual (Psi) - Other Well  
Flow (Gpm) - Proof Flow Gpm  
S Elevation -

P Location:  
P  
L Source of Information:  
Y

# Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.  
243 STATE STREET HC2


Page 2  
Date 7/12/11

### Pump Data:

P1 - Pump Churn Pressure : 55  
 P2 - Pump Rated Pressure : 50  
 P2 - Pump Rated Flow : 50  
 P3 - Pump Pressure @ Max Flow : 32.5  
 P3 - Pump Max Flow : 75

### Demand:

D1 - Elevation : 12.703  
 D2 - System Flow : 49.3439  
 D2 - System Pressure : 44.081  
 Hose ( Adj City ) : \_\_\_\_\_  
 Hose ( Demand ) : \_\_\_\_\_  
 D3 - System Demand : 49.3439  
 Safety Margin : 6.086



# Fittings Used Summary

FREEDOM FIRE PROTECTION INC.  
243 STATE STREET HC2

Page 3  
Date 7/12/11

Fitting Legend																					
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.  
243 STATE STREET HC2

Page 4  
Date 7/12/11

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
201	29.33	4.2	15.61	na	16.59	0.05	0.001	14.5
27	29.33		17.24	na				
26	29.33		17.36	na				
203	29.33	4.2	14.5	na	15.99	0.05	0.001	14.5
202	29.33	4.2	15.92	na	16.76	0.05	0.001	14.5
25	29.33		16.62	na				
24	29.33		17.05	na				
23	29.33		17.43	na				
22	29.33		19.16	na				
21	17.67		29.24	na				
20	17.67		31.43	na				
2	7.66		37.91	na				
1	1.0		43.47	na				
TEST	0.0		44.08	na				

The maximum velocity is 10.58 and it occurs in the pipe between nodes 23 and 22

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.  
243 STATE STREET HC2

Page 5  
Date 7/12/11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
201 to 27	16.59	1.049 120	4E 8.0 0.0	9.750 8.000	15.608 0.0			K Factor = 4.20	
27 to 26	16.59	0.0921 120	0.0 1E 3.0	17.750 2.000	1.635 17.243			Vel = 6.16	
26 to 23	0.0	1.38 120	0.0 0.0	3.000 5.000	0.0 0.121			Vel = 3.56	
23 to 0.0	16.59	0.0244 120	0.0 0.0	2.830 0.0	0.069 0.0			Vel = 3.56	
0.0 to 203	16.59				17.433			K Factor = 3.97	
203 to 202	15.99	1.049 120	1E 2.0 1T 5.0	9.500 7.000	14.500 0.0			K Factor = 4.20	
202 to 25	15.99	0.0861 120	0.0 1E 3.0	16.500 5.250	1.420 15.920			Vel = 5.94	
25 to 24	16.76	1.38 120	0.0 0.0	3.000 8.250	0.0 0.703			K Factor = 4.20	
24 to 23	32.75	0.0852 120	0.0 1E 3.0	2.000 3.000	16.623 0.0			Vel = 7.02	
23 to 22	0.0	1.38 120	0.0 0.0	3.000 5.000	0.0 0.426			Vel = 7.02	
22 to 21	32.75	0.0853 120	0.0 0.0	4.500 0.0	17.049 0.0			Vel = 7.02	
21 to 20	32.75	0.0853 120	0.0 1T 6.0	4.500 3.500	0.384 17.433			Vel = 7.02	
20 to 20	16.59	1.38 120	1T 6.0 0.0	3.500 6.000	17.433 0.0			Vel = 10.58	
20 to 2	49.34	0.1819 120	0.0 1T 6.0	9.500 21.660	1.728 19.161			Vel = 10.58	
2 to 1	0.0	1.38 120	0.0 0.0	6.000 6.000	5.050 5.033			Vel = 10.58	
1 to TEST	49.34	0.1820 120	0.0 1E 3.0	27.660 3.000	5.033 29.244			Vel = 10.58	
TEST to 1	49.34	0.1819 120	0.0 1T 6.0	12.000 9.000	2.183 0.0			Vel = 10.58	
1 to 1	0.0	1.38 120	0.0 0.0	5.830 6.000	31.427 4.335			Vel = 10.58	
1 to 1	49.34	0.1819 120	0.0 0.0	11.830 7.000	2.152 2.884			Vel = 10.58	
1 to 1	0.0	1.38 120	0.0 0.0	7.660 7.000	37.914 2.884			Vel = 10.58	
1 to TEST	49.34	0.1820 120	0.0 0.0	14.660 1.000	2.668 43.466			Vel = 10.58	
TEST to 0.0	49.34	0.1820 120	0.0 0.0	1.000 0.0	0.182 0.433			Vel = 10.58	
0.0	0.0								

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.  
243 STATE STREET HC2

Page 6  
Date 7/12/11

---

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	49.34				44.081			K Factor =	7.43

---