

## Marge Schmuckal - Re: 46 Avon Street

---

**From:** John Martell  
**To:** Marge Schmuckal  
**Date:** 2/6/2013 4:19 PM  
**Subject:** Re: 46 Avon Street

---

Marge,

I just visited the site again. Tim will be required to have the 2nd means of egress and there is no way for an internal stair to be constructed. The only other option for him is the external stairs which he has applied for. Let me know if you need any other type of verification from our office for you to make your decision. Thanks Marge  
John

John Martell  
Portland Fire Department  
Fire Prevention Bureau  
874-8400