

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

RECORD BETHANY & WESTLEY CORBIN JTS

Located at

29 DEERING ST Unit 2

PERMIT ID: 2017-01076

ISSUE DATE: 10/23/2017

CBL: 046 A012002

has permission to **Renovate Unit 2 condominium: remove rear stairs, relocate bathroom, frame new bedroom, insulation, and replace one window for egress**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

residential condominium unit (3 total in building)

Building Inspections

Use Group: R2

Type: 5B

3 family Residence

Non Sprinkled

ENTIRE

2009 IBC / MUBEC

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing
Electrical - Commercial
Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-01076	Date Applied For: 06/30/2017	CBL: 046 A012002
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Residential Condo		Proposed Project Description: Renovate Unit 2 condominium: remove rear stairs, relocate bathroom, frame new bedroom, insulation, and replace one window for egress		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Deborah Andrews	Approval Date: 08/22/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) New casement egress window shall the appearance of the double-hung window it will replace. Casement to include simulated horizontal meeting rail.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 07/17/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note: R-6 zone				
Conditions:				
1) This unit shall remain a residential condominium unit for single-family use only. Any change of use shall require a separate permit application for review and approval.				
2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving work within the existing footprint and shell only.				
3) ANY exterior work requires a review and approval from Historic Preservation. This property is located within a Historic District.				
4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 10/23/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Existing stair to be closed off at the first floor as non functioning life safety feature				
2) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code				
4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 10/11/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Every sleeping and living area in a residential occupancy shall have at least 1 primary means of escape and 1 secondary means of escape. The secondary means of escape may be an outside egress window operable from the inside without the use of tools, keys or special effort. In buildings built before 1976, egress windows shall provide a net clear opening 3.3 sq. ft. The width shall not be less than 20 inches and height shall not be less than 24 inches. The bottom of the window opening shall not be more than 44 inches above the floor unless a permanent step is installed.				
2) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.				
1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas				
2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.				

PERMIT ID: 2017-01076

Located at: 29 DEERING ST Unit 2

CBL: 046 A012002

- 3) City of Portland Code Chapter 10 section 10-3 (i) all new smoke alarm must use photoelectric technology. In existing apartment building smoke detectors must be powered by the buildings electrical service and must have a secondary power source (battery). Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
1. Inside all sleeping rooms.
 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 4) All penetrations for cables, cable trays, conduits, pipes, tubes, vents, ducts, wires and similar items that pass through or penetrate a fire rated wall ceiling or floor assembly shall be protected and sealed by a listed firestop system and installed to comply with the systems manufactures recommendation.
Fire resistant paint must be applied and maintained according to manufacture recommendations.
- 5) The means of egress shall be illuminated and marked in accordance with 2009 NPFA 101, sections 7.8 and 7.10.
- 6) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
If applicable, all outstanding code violations shall be corrected prior to final inspection.