



March 23, 2016

FLYNN KATHERINE

452 CUMBERLAND AVE

PORTLAND, ME 04101

CBL: 046 B002001

Located at 452 CUMBERLAND AVE

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "Capt. D. Petrucci".

Portland Fire Department

Fire Prevention Bureau

CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT

380 Congress Street  
Portland, Maine 04101

Inspection Violations

<b>Owner/Manager</b> FLYNN KATHERINE		<b>Inspector</b> Chad Johnston	<b>Inspection Date</b> 3/22/2016
<b>Location</b> 452 CUMBERLAND AVE	<b>CBL</b> 046 B002001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 69.20

**Violation:** PORTLAND FIRE DEPARTMENT CHAPTER 10 SECTION 12 KNOX BOX REQUIRED; KNOX BOXES ARE REQUIRED FOR ALL BUILDINGS WITH FIRE ALARM OR SUPPRESSION SYSTEMS.

**Notes:** 6 UNIT BLDG W/ MONITORED FIRE ALARM SYSTEM

2) 80.40

**Violation:** NFPA 101- 31.2.2.1.2 EXIT STAIR REQ 60-MIN FIRE DOORS - NON-HIGH-RISE; IN BUILDINGS USING OPTION 4, EXIT ENCLOSURES SHALL HAVE A MINIMUM 1-HOUR FIRE RESISTANCE RATING, AND DOORS SHALL HAVE A MINIMUM 1-HOUR FIRE PROTECTION RATING.

**Notes:** INTERIOR DOORS NON-FIRE RATED

**Comments:**

STATE OF MAINE

DISTRICT COURT  
Location: Portland  
Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

v.

Katherine Flynn  
Defendant


**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

SUMMONS NUMBER: 354549

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 07/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 07/11/2016.

Dated: 4/25/16



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Counsel  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480