



Planning &amp; Urban Development Department

Director of Planning and Urban Development  
Jeff LevineInspection Services, Director  
Tammy M. Munson

February 3, 2015

STRAND JEROME J  
PO BOX 5222  
PORTLAND, ME 04101**CBL: 046 B007004**  
**Located at: 198 HIGH ST****Certified Mail 7010 3090 0002 3273 7897**

Dear Mr. Strand,

An evaluation of the above-referenced property on **02/03/2015** shows that the structure fails to comply with Chapter 6. Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within **14 days** of the date of this notice. A re-inspection of the premises will occur On **02/17/2015** at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Sincerely,

A handwritten signature in black ink, appearing to read "Chuck Fagone".

Chuck Fagone  
Code Enforcement Officer  
(207) 874-8789

---

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> STRAND JEROME J		<b>Inspector</b> Chuck Fagone	<b>Inspection Date</b> 2/3/2015
<b>Location</b> 198 HIGH ST	<b>CBL</b> 046 B007004	<b>Status</b> Re-Inspect 14 Days	<b>Inspection Type</b> Complaint-Inspection

---

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
-------------	----------------	--------------	-----------------	-------------	------------------------

---

1) 6-116. (e) Interior Smoke Alarms

**Violation:** FIRE PROTECTION

**Notes:** Every dwelling, dwelling unit, rooming house and rooming unit shall comply with the applicable provisions of the most current edition of the National Fire Protection Association Life Safety Code, and with all other applicable state statutes and regulations.

*A combination smoke and carbon monoxide photo electric detector will need to be reinstalled*

---

Portland, Maine




Yes. Life's good here.

Planning & Urban Development  
Inspection Division

389 Congress Street, Room 315  
Portland, Maine 04101-3509

RETURN TO  
SENDER  
**UNCLAIMED**

PRESORTED  
FIRST CLASS



UNITED STATES POSTAGE



PITNEY BOWES

02 1M  
0004222549

**\$ 00.38<sup>1</sup>**  
FEB 05 2015

MAILED FROM ZIP CODE 04101

NIXIE 015 CE 1300 7206/18/15

RETURN TO SENDER  
NOT DELIVERABLE AS ADDRESSED  
UNABLE TO FORWARD

BC: 04101357190 \*1369-10538-17-38

04101357190

