

# ELECTRICAL PERMIT

## City of Portland, Me.



874 8703

To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical Code and the following specifications:

Date \_\_\_\_\_  
 Permit # 2010-4590  
 CBL# 46-B-12

LOCATION: 180 HIGH ST. #12 METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # \_\_\_\_\_ OWNER \_\_\_\_\_  
 TENANT \_\_\_\_\_ PHONE # \_\_\_\_\_

						TOTAL EACH FEE	
OUTLETS	8	Receptacles	Switches	Smoke Detector		.20	\$1.60
FIXTURES		Incandescent	Fluorescent	Strips		.20	
SERVICES		Overhead	Underground	TTL AMPS <800		15.00	
		Overhead	Underground	TTL AMPS >800		25.00	
Temporary Service		Overhead	Underground	TTL AMPS		25.00	
						25.00	
METERS		(number of)				1.00	
MOTORS		(number of)				2.00	
RESID/COM		Electric units				1.00	
HEATING		oil/gas units	Interior	Exterior		5.00	
APPLIANCES		Ranges	Cook Tops	Wall Ovens		2.00	
		Insta-Hot	Water heaters	Fans		2.00	
		Dryers	Disposals	Dishwasher		2.00	
		Compactors	Spa	Washing Machine		2.00	
		Others (denote)				2.00	
MISC. (number of)		Air Cond/win				3.00	
		Air Cond/cent		Pools		10.00	
		HVAC	EMS	Thermostat		5.00	
		Signs				10.00	
		Alarms/res				5.00	
		Alarms/com				15.00	
		Heavy Duty(CRKT)				2.00	
		Circus/Carnv				25.00	
		Alterations				5.00	
		Fire Repairs				15.00	
		E Lights				1.00	
		E Generators				20.00	
	PANELS		Service	Remote	Main		4.00
TRANSFORMER		0-25 Kva				5.00	
		25-200 Kva				8.00	
		Over 200 Kva				10.00	
						TOTAL AMOUNT DUE	
						MINIMUM FEE/COMMERCIAL 55.00	MINIMUM FEE 45.00

RECEIVED  
 AUG 26 2010  
 Dept. of Building Inspections  
 City of Portland Maine

CONTRACTORS NAME ROBERT CYR MASTER LIC. # MC60018809  
 ADDRESS P.O. BOX 146, LIMINGTON, ME LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 207-637-2913 04049-0146

SIGNATURE OF CONTRACTOR BOB CYR / W.D.

**ELECTRICAL INSTALLATIONS**

Permit Number \_\_\_\_\_

Location \_\_\_\_\_

Owner \_\_\_\_\_

Date of Permit \_\_\_\_\_

Final Inspection \_\_\_\_\_

By Inspector \_\_\_\_\_

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_

Service called in \_\_\_\_\_

Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:

REMARKS:

9/17/2010 NO one there - Reschedule inspection Per electrician BKL

11/18/2010 Need GFCI in BATHROOM, Fix wiring to chandeliers, LABEL Electric Panel, Put LT in Bathroom (unit?) BKL

RECEIVED

Handwritten notes and stamps at the bottom of the page, including a circular stamp and various illegible text.