

FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM INSPECTION AND TESTING FORM

*To be completed by the system inspector or tester at the time of the inspection or test.
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.
Insert N/A in all unused lines.*

Attach additional sheets, data, or calculations as necessary to provide a complete record.

Date of this inspection or test: 12-21-15

Time of inspection or test: 13:30

1. PROPERTY INFORMATION

Name of property: DRE MANAGEMENT ACT# 5060-2929 PORTLAND STICKER #15-0532

Address: 209 STATE STREET PORTLAND ME 04101

Description of property: 3 UNIT 8 UNIT APARTMENT COMPLEX

Occupancy type: EXISTING APARTMENT BUILDING

Name of property representative: DRE MANAGEMENT/ RON DUBOIS

Address: 318 BRIGHTON, AVE PORTLAND MAINE 04102

Phone: 207-329-6993

Fax:

E-mail: rdubois1@maine.rr.com

Authority having jurisdiction over this property: PORTLAND FIRE DEPT

Phone: 874-8405

Fax:

E-mail: fireinspector@portlandme.gov

2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Service and/or testing organization for this equipment: MAINE STATE SECURITY

Address: 1308 NEW COUNTY ROAD, DAYTON MAINE 04005

Phone: 207-247-4371

Fax: 207-929-8484

E-mail: INFO@MAINESTATESECURITY.COM

Service technician or tester: CHRIS LHEUREUX

Qualifications of technician or tester: LM50017202, IMSA L2, NTS FIRE TECH

A contract for test and inspection in accordance with NFPA standards is in effect as of:

The contract expires: AUTO

RENEWAL

Contract number:

Frequency of tests and inspections: annual

Monitoring organization for this equipment: CENTRA-LARM

A contract for test and inspection in accordance with NFPA standards is in effect as of: 12-21-15

Address: 994 CANDIA ROAD MANCHESTER NH

Phone: 1-800-639-2066

Fax:

E-mail:

Entity to which alarms are retransmitted: PORTLAND FIRE DISPATCH

Phone: 207-874-8576

3. TYPE OF SYSTEM OR SERVICE

Fire alarm system (nonvoice)

Fire alarm with in-building fire emergency voice alarm communication system (EVACS)

Mass notification system (MNS)

Combination system, with the following components:

Fire alarm

EVACS

MNS

Two-way, in-building, emergency communication system

NFPA 72, Fig. 14.6.2.4 (p. 1 of 11)

Other (specify):

3. TYPE OF SYSTEM OR SERVICE (continued)

NFPA 72 edition: 2110

Additional description of system(s):

3.1 Control Unit

Manufacturer: SILENT KNIGHT

Model number: IFP 50

3.2 Mass Notification System

This system does not incorporate an MNS

3.2.1 System Type:

In-building MNS—combination

In-building MNS—stand-alone Wide-area MNS Distributed recipient MNS

Other (specify):

3.2.2 System Features:

Combination fire alarm/MNS MNS ACU only Wide-area MNS to regional national alerting interface

Local operating console (LOC) Direct recipient MNS (DRMNS) Wide-area MNS to DRMNS interface

Wide-area MNS to high-power speaker array (HPSA) interface In-building MNS to wide-area MNS interface

Other (specify):

3.3 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the record record drawings are stored on site. Location: BASEMENT ELECTRICAL ROOM BELOW FIRE PANEL

3.4 System Software

This system does not have alterable site-specific software.

Software revision number: 15

Software last updated on: 12-21-15

A copy of the site-specific software is stored on site. Location: DOC BOX USB DEVICE

4. SYSTEM POWER

4.1 Control Unit

4.1.1 Primary Power

Input voltage of control panel: 120V

Control panel amps: 3

4.1.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

4.1.3 Uninterruptible Power System

This system does not have UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

4. SYSTEM POWER (continued)

4.1.4 Batteries

Location: IN PANEL Type: SLA Nominal voltage: 12 Amp/hour rating: 7

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 5

Batteries are marked with date of manufacture.

4.2 In-Building Fire Emergency Voice Alarm Communication System or Mass Notification System

This system does not have an EVACS or MNS.

4.2.1 Primary Power

Input voltage of EVACS or MNS panel: EVACS or MNS panel amps:

4.2.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage: Type of fuel:

4.2.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours): In alarm mode (minutes):

4.2.4 Batteries

Location: Type: Nominal voltage: Amp/hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours): In alarm mode (minutes):

Batteries are marked with date of manufacture.

4.3 Notification Appliance Power Extender Panels

This system does not have power extender panels.

4.3.1 Primary Power

Input voltage of power extender panel(s): Power extender panel amps:

4.3.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage: Type of fuel:

4.3.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours): In alarm mode (minutes):

4. SYSTEM POWER (continued)

4.3.4 Batteries

Location: _____ Type: _____ Nominal voltage: _____ Amp/hour rating: _____
 Calculated capacity of batteries to drive the system: _____
 In standby mode (hours): _____ In alarm mode (minutes): _____
 Batteries are marked with date of manufacture.

5. ANNUNCIATORS

This system does not have annunciators.

5.1 Location and Description of Annunciators

Annunciator 1: FRONT ENTRY 1ST FLOOR
 Annunciator 2:
 Annunciator 3:

6. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization Contact: BOLD MOBILE Time: 1330
 Building management Contact: DRE MANAGEMENT/RON DUBOIS Time: 1300
 Building occupants Contact: Time:
 Authority having jurisdiction Contact: Time:
 Other, if required Contact: Time:

7. TESTING RESULTS

7.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Lamps/LEDs/LCDs	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Fuses	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Trouble signals	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Disconnect switches	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Ground-fault monitoring	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Supervision	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Local annunciator	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Remote annunciators	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Power extender panels	<input type="checkbox"/>	<input type="checkbox"/>	
Isolation modules	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.2 Control Unit Power Supplies

Description	Visual Inspection	Functional Test	Comments
120-volt power	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	HOUSE PANEL CKT 10 #1 13.29V 7.3AH #2 13.32V 7.4AH
Generator or UPS	<input type="checkbox"/>	<input type="checkbox"/>	
Battery condition	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Load voltage	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Discharge test	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Charger test	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.3 In-Building Fire Emergency Voice Alarm Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	<input type="checkbox"/>	<input type="checkbox"/>	
Lamps/LEDs/LCDs	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Secondary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
Panel supervision	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No Ambient dBA Alarm dBA (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility <input type="checkbox"/> CSI <input type="checkbox"/> STI (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.4 Notification Appliance Power Extender Panels

Description	Visual Inspection	Functional Test	Comments
Lamps/LEDs/LCDs	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Secondary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
Panel supervision	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.5 Mass Notification Equipment

Description	Visual Inspection	Functional Test	Comments
Functional test	<input type="checkbox"/>	<input type="checkbox"/>	
Reset/power down test	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
UPS power test	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
CCU security mechanism	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message content	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message activation	<input type="checkbox"/>	<input type="checkbox"/>	
Software backup performed	<input type="checkbox"/>	<input type="checkbox"/>	
Test backup software	<input type="checkbox"/>	<input type="checkbox"/>	
Fire alarm to MNS interface	<input type="checkbox"/>	<input type="checkbox"/>	
MNS to fire alarm interface	<input type="checkbox"/>	<input type="checkbox"/>	
In-building MNS to wide-area MNS	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.5 Mass Notification Equipment (continued)

Description	Visual Inspection	Functional Test	Comments
MNS to direct recipient MNS	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No Ambient dBA Alarm dBA (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility <input type="checkbox"/> CSI <input type="checkbox"/> STI (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify) _____	<input type="checkbox"/>	<input type="checkbox"/>	

7.6 Two-Way Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Phone handsets	<input type="checkbox"/>	<input type="checkbox"/>	
Phone jacks	<input type="checkbox"/>	<input type="checkbox"/>	
Off-hook indicator	<input type="checkbox"/>	<input type="checkbox"/>	
Call-in signal	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
System audibility	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility	<input type="checkbox"/>	<input type="checkbox"/>	
Radio communications enhancement system	<input type="checkbox"/>	<input type="checkbox"/>	
Area of refuge communication system	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator emergency communications system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify) _____	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.7 Combination Systems

Description	Visual Inspection	Functional Test	Comments
Fire extinguishing monitoring devices/system	<input type="checkbox"/>	<input type="checkbox"/>	FURNACE ROOM 0PPM
Carbon monoxide detector/system	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Combination fire/security system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.8 Special Hazard Systems

Description (specify)	Visual Inspection	Functional Test	Comments
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	

7.9 Emergency Communications System

- Visual
- Functional
- Simulated operation
- Ensure predischage notification appliances of special hazard systems are not overridden by the MNS.
See *NFPA 72, 24.4.1.7.1.*

7.10 Monitored Systems

Description (specify)	Visual Inspection	Functional Test	Comments
Engine-driven generator	<input type="checkbox"/>	<input type="checkbox"/>	
Fire pump	<input type="checkbox"/>	<input type="checkbox"/>	
Special suppression systems	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.11 Auxiliary Functions

Description	Visual Inspection	Functional Test	Comments
Door-releasing devices	<input type="checkbox"/>	<input type="checkbox"/>	
Fan shutdown	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke management/smoke control	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke damper operation	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke shutter release	<input type="checkbox"/>	<input type="checkbox"/>	
Door unlocking	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator recall	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator shunt trip	<input type="checkbox"/>	<input type="checkbox"/>	
MNS override of FA signals	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.12 Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.13 Supervisory Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.14 Alarm Notification Appliances

Appliance test results sheet attached listing all appliances tested and the results of the testing

7.15 Supervisory Station Monitoring

Description	Visual Inspection	Functional Test	Time	Comments
Alarm signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	
Alarm restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	
Trouble signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	
Trouble restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	
Supervisory signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	
Supervisory restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1330-1700	

8. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization	Contact: BOLD MOBILE	Time: 1700
Building management	Contact: DRE MANAGEMENT/RON DUBOIS	Time: 1700
Building occupants	Contact:	Time:
Authority having jurisdiction	Contact:	Time:
Other, if required	Contact:	Time:


9. SYSTEM RESTORED TO NORMAL OPERATION

Date: 12-21-15 Time: 1700

10. CERTIFICATION

10.1 Inspector Certification:

This system, as specified herein, has been inspected and tested according to all NFPA standards cited herein.

Signed:  , Printed name: CHRIS LHEUREUX Date: 12-21-15
Organization: MSS Title: FIRE TECH Phone: 207-247-4371

10.2 Acceptance by Owner or Owner's Representative:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed: Printed name: RON DUBOIS Date: 12-21-15
Organization: DRE MGMT Title: OWNER Phone: 207-329-6993



DRE Management
 209 State Street
 Portland Maine 04101

Date: 12/21/15
 Tester: C. L'Heureux

Point ID	Point Name	Point Type:Sensitivlty	Results
33:s001	BASEMENT ELECTRICAL	Init:Addr:Detector:Photo:3.5%	Z1 / Passed
33:s003	BASEMENT MIDDLE	Init:Addr:Detector:Photo 3.5%	Z3 / Passed
33:s004	BASEMENT FURNACE RM	Init:Addr:Detector:Photo 3.5%	Z4 / Passed
33:s005	BASEMENT FURNACE RM	Init:Addr:Detector:Alarm CO/Alarm Fire	Z5 / Passed
33:s008	SIDE UNITS 2 &3	Init:Addr:Detector:Photo 3.5%	Z8 / Passed
33:s010	1ST FLR FRONT STAIRS	Init:Addr:Detector:Photo 3.5%	Z10 / Passed
33:s012	2ND FLR FRONT STAIRS	Init:Addr:Detector:Photo 3.5%	Z12 / Passed
33:s014	3RD FLR FRONT STAIRS	Init:Addr:Detector:Photo 3.5%	Z14 / Passed
33:s015	3RD FLOOR MIDDLE	Init:Addr:Detector:Photo 3.5%	Z15 / Passed
33:s016	ATTIC	Init:Addr:Detector:Heat 135	Z16 / Passed
33:s017	3RD FLOOR BACK HALL	Init:Addr:Detector:Photo 3.5%	Z17 / Passed
33:s019	3RD FLOOR BACK STAIR	Init:Addr:Detector:Photo 3.5%	Z19 / Passed
33:s021	2ND FLOOR BACK STAIR	Init:Addr:Detector:Photo 3.5%	Z21 / Passed
33:s023	1ST FLOOR BACK STAIR	Init:Addr:Detector:Photo 3.5%	Z23 / Passed
33:m002	BASEMENT	Init:Addr:Switch:Manual Pull	Z2 / Passed
33:m007	SIDE UNITS 2 &3	Init:Addr:Switch:Manual Pull	Z7 / Passed
33:m009	1ST FLR FRONT STAIRS	Init:Addr:Switch:Manual Pull	Z9 / Passed
33:m011	2ND FLR FRONT STAIRS	Init:Addr:Switch:Manual Pull	Z11 / Passed
33:m013	3RD FLR FRONT STAIRS	Init:Addr:Switch:Manual Pull	Z13 / Passed
33:m018	3RD FLR BACK STAIRS	Init:Addr:Switch:Manual Pull	Z18 / Passed
33:m020	2ND FLR BACK STAIRS	Init:Addr:Switch:Manual Pull	Z20 / Passed
33:m022	1ST FLR BACK STAIRS	Init:Addr:Switch:Manual Pull	Z22 / Passed
34:001	NOTIFICATION CKT 1	Notif:Conv:	G1 / Passed
34:002	NOTIFICATION CKT 2	Notif:Conv:	G1 / Passed
34:003	MODULE 34 RELAY 1	Notif:Conv:Relay:	G124/ Not Used
34:004	MODULE 34 RELAY 2	Notif:Conv:Relay:	G125 / Not used