Maine State Security Services

A Division of L'Heureux Inc.

1308 New County RD Dayton, ME 04005
Tel: 207-247-4371
Fax: 207-929-8484
Email: info@mainestatesecurity.com

CITY OF PORTLAND, MAINE · RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/14/15

October 30, 2015

Portland Fire Prevention
380 Congress Street
Portland, Me 04101

Re: 209 State Street

Scope of work: We intend to install a Fire Alarm System for the building, This is a 3 story apartment building that doesn't require a fire alarm system under NPFA 101, but as an alternative to replacing corridor doors with ones that are fire rated owner has come up with an agreement with the city to provide a fire alarm system in the common area's and have that system monitored. We will be placing smoke detectors in the common halls and staircases, pull stations by all exits and heat and smoke detection in the basement. The system will be all hard wired devices all UL listed for commercial fire. Fire Alarm control panel will be located in the basement with an annunicatior by the main entry, Communication to the UL listed Remote Station will be accomplished by using a commercial Fire Alarm Cellular (GSM) Communicator.

Please feel free to give me a call after reviewing the submittals if you have any questions.

Sincerely,

Chris L'Heureux

Digitally signed by Chris L'Heureux
DN: cn=Chris L'Heureux, o=L'Heureux Inc, ou=Maine State Security, email=info@mainestatesecurity.com, c=US
Date: 2015.11.17 07:51:07 -05'00'

Chris L'Heureux