

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

WILLISTON-IMMANUEL UNITED CHURCH

Located at

156 HIGH ST (2nd floor)

PERMIT ID: 2013-01589

ISSUE DATE: 08/27/2013

CBL: 046 D017001

has permission to **Change of Use to include child care/school for up to 12 children on the 2nd floor, no construction**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group: I-4 (B & Type: 3B
A)

Classification:

Day Care - 2nd Floor of Parish House
(Max. 12 children)

Day-care Occupancy

Entire

FI 2

MUBEC/IBC 2009

2009 NFPA

PERMIT ID: 2013-01589

Located at: 156 HIGH ST (2nd floor)

CBL: 046 D017001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01589	Date Applied For: 07/24/2013	CBL: 046 D017001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Church Parish House with childcare/school on the 2nd Floor	Proposed Project Description: Change of Use to include child care/school for up to 12 children on the 2nd floor, no construction			
Dept: Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal Approval Date: 07/26/2013 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Separate permits shall be required for any new signage. 2) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
Dept: Building Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 08/27/2013 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved for compliance with the State of Maine adoption of MUBEC, as revised. This designates the State Fire Marshal and DHHS to regulate compliance of this structure for the proposed Child Care Provider. Http://www.maine.gov/dps/fmo/documents/ChildCareFacility.pdf 3) This is a Change of Use ONLY permit. It does NOT authorize any construction activities. 4) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 08/06/2013 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Shall comply with 2009 NFPA 101 Chapter 16 New Day Care Occupancies pay special attention 16.6.1.4.1.2 2) All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf				