

MIDCOAST ENVIRONMENTAL, INC.
P.O. BOX 34
BRUNSWICK, MAINE 04011

CERTIFICATE OF RE-OCCUPANCY

CLIENT: BIOSAFE ENVIRONMENTAL


PROJECT: PORTLAND HALL, USM – PORTLAND, MAINE

MIDCOAST #: 09 - 0053

BUILDING: A – WING CONNECTOR [FROM MAIN BUILDING]

WORK AREA: STAIRWELL AREA

The airborne fiber concentration in the work area has been determined to be below the Environmental Protection Agency recommended safe level for re-occupancy of ≤ 0.010 f/cc. The MidCoast Environmental representative has declared this area available for re-occupancy by unprotected personnel on the 1st day of May 2009 at 1230 hours.



Clayton C. Collins (ME. DEP #AA-0111)
President
MIDCOAST ENVIRONMENTAL, INC.

MAY 1, 2009
Date


MIDCOAST ENVIRONMENTAL, INC.
P.O. BOX 34
BRUNSWICK, MAINE 04011

CERTIFICATE OF RE-OCCUPANCY

MAY 18 2009

CLIENT: BIOSAFE ENVIRONMENTAL
PROJECT: PORTLAND HALL, USM – PORTLAND, MAINE
MIDCOAST #: 09 - 0046
BUILDING: MAIN
WORK AREA: BASEMENT

The airborne fiber concentration in the work area has been determined to be below the Environmental Protection Agency recommended safe level for re-occupancy of ≤ 0.010 f/cc. The MidCoast Environmental representative has declared this area available for re-occupancy by unprotected personnel on the 23rd day of April 2009 at 1530 hours.



Clayton C. Collins (ME. DEP #AA-0111)
President
MIDCOAST ENVIRONMENTAL, INC.

APRIL 23, 2009
Date


**MIDCOAST ENVIRONMENTAL, INC.
P.O. BOX 34
BRUNSWICK, MAINE 04011**

MAY 18 2009

CERTIFICATE OF RE-OCCUPANCY

CLIENT: BIOSAFE ENVIRONMENTAL
PROJECT: PORTLAND HALL, USM -- PORTLAND, MAINE
MIDCOAST #: 09 - 0047
BUILDING: MAIN
WORK AREA: BOILER ROOM

The airborne fiber concentration in the work area has been determined to be below the Environmental Protection Agency recommended safe level for re-occupancy of ≤ 0.010 f/cc. The MidCoast Environmental representative has declared this area available for re-occupancy by unprotected personnel on the 24th day of April 2009 at 1530 hours.



Clayton C. Collins (ME. DEP #AA-0111)
President
MIDCOAST ENVIRONMENTAL, INC.

APRIL 24, 2009
Date


MIDCOAST ENVIRONMENTAL, INC.
P.O. BOX 34
BRUNSWICK, MAINE 04011

MAY 19 2009

CERTIFICATE OF RE-OCCUPANCY

CLIENT: BIOSAFE ENVIRONMENTAL
PROJECT: PORTLAND HALL, USM – PORTLAND, MAINE
MIDCOAST #: 09 - 0050
BUILDING: MAIN
WORK AREA: BOILER ROOM

The airborne fiber concentration in the work area has been determined to be below the Environmental Protection Agency recommended safe level for re-occupancy of ≤ 0.010 f/cc. The MidCoast Environmental representative has declared this area available for re-occupancy by unprotected personnel on the 29th day of April 2009 at 1045 hours.



Clayton C. Collins (ME. DEP #AA-0111)
President
MIDCOAST ENVIRONMENTAL, INC.

APRIL 29, 2009
Date