

INSTALL DETECTORS AND WIRING IN CONFORMANCE WITH STATE ELEVATOR CODE.

ELEVATOR FIRE ALARM INTERFACE WIRING DIAGRAM

NOT TO SCALE



SINGLE LINE DIAGRAM

NOT TO SCALE



TYPICAL LIGHTING CONTROL DIAGRAM

NOT TO SCALE



FIRE ALARM RISER DIAGRAM NOTES:

1. PROVIDE A TAMPER AND FLOW SWITCH AT EACH SPRINKLER MAIN VALVE.

FIRE ALARM RISER DIAGRAM

NOT TO SCALE



SECURITY SYSTEM WIRING DIAGRAM NOTES:

1. PROVIDE ALL NECESSARY INTER–CONNECTING WIRING TO MAKE A COMPLETE AND FUNCTIONING SYSTEM.
2. WIRING SHALL BE #22 AWG (SHIELDED).
3. PROVIDE KEYPAD STATION.

SECURITY SYSTEM WIRING DIAGRAM

NOT TO SCALE

STATE OF MAINE
LAWRENCE E. BARTLETT
No. 7928
LICENSED PROFESSIONAL ENGINEER
Lawrence E. Bartlett

Prepared For:
NORTHLAND ENTERPRISES, LLC
ONE CITY CENTER - 4TH FLOOR
PORTLAND, ME 04101

Consulting Engineer:

Architect:
ARCHETYPE Architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
The BAXTER LIBRARY
619 CONGRESS STREET
PORTLAND, MAINE

Revisions:

Scale: None

Date: 4 Sept. 2009

ELECTRICAL DIAGRAMS

E3.01