Inspections Division
Date: 01/21/14

Marge Schmuckal - Sidewalk sign application - 2014-00060 - 046-D-031

From: Marge Schmuckal
To: flick18park@gmail.com
Date: 1/14/2014 11:32 AM
Subject: Sidewalk sign application - 2014-00060 - 046-D-031

Hi Thomas,
I am reviewing your application for a sidewalk sign. One of the requirements for such signs is that the maximum height in place is 40 inches. the only dimension that you gave us is that the actual sign is 46 inches in height.
Can you give me confirmation as to the height of your sign when it is in place?
I can not sign off on your permit until I have that compliance information.
Marge Schmuckal
Zoning Administrator
City of Portland, Maine