Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/01/15

Portland, Maine — Yes. Life's good here.

Jeff Levine, AICP, Director
Planning & Urban Development Department

Ann Machado
Zoning Administrator

NFPA LIFE SAFETY CODE – FIRE PREVENTION CODE
DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal non-conforming dwelling units to become legalized through a given process. Part of this process is that the dwelling units that are requested to be legalized MUST comply, or be able to comply, with the NFPA Life Safety Code – Fire Prevention Code, PRIOR to issuing the requested permit.

Please return this form to the Zoning Administrator as to compliance or the ability to comply with these codes.

Location: 773 Congress St ~~125-E-006~~ 47-A-11

Owner: East-End Corp

Address of owner: PO Box 10291, Portland ME 04104 879-6081
(If different)

Applicant Information:
(If different):

Current number of legal units: one (1)

Number of units to be legalized: three (3)
total: four (4) *there is an existing office on part of the 1st floor

Comments of approval or disapproval (List any and all conditions):
- Fire doors are required (several locations)
- Unit 5B requires number - Hardwired battery back-up smoke and CO detection required (several locations).

Signature: [signature] Date: 9/21/2015