



Jeff Levine, AICP, Director  
 Planning & Urban Development Department

Tammy Munson, Director  
 Inspections Division

**Fire Department requirements.**

The following shall be submitted on a separate sheet:

- Name, address and phone number of applicant **and** the project architect.
- Proposed use of structure (NFPA and IBC classification)
- Square footage of proposed structure (total and per story)
- Existing and proposed fire protection of structure.
- Separate plans shall be submitted for
  - a) Suppression system
  - b) Detection System (separate permit is required)
- A separate Life Safety Plan must include:
  - a) Fire resistance ratings of all means of egress
  - b) Travel distance from most remote point to exit discharge
  - c) Location of any required fire extinguishers d)
  - Location of emergency lighting
  - e) Location of exit signs
  - f) NFPA 101 code summary
- Elevators shall be sized to fit an 80" x 24" stretcher.

For questions on Fire Department requirements call the Fire Prevention Officer at (207) 874-8405.

**Please submit all of the information outlined in this application checklist. If the application is incomplete, the application may be refused.**

In order to be sure the City fully understands the full scope of the project, the Planning and Development Department may request additional information prior to the issuance of a permit. For further information or to download copies of this form and other applications visit the Inspections Division on-line at [www.portlandmaine.gov](http://www.portlandmaine.gov), or stop by the Inspections Division office, room 315 City Hall or call 874-8703.

Permit Fee: ~~\$30.00~~ <sup>\$25.00</sup> for the first \$1000.00 construction cost, \$10.00 per additional \$1000.00 cost <sup>\$100 cofe.</sup>

**This is not a Permit; you may not commence any work until the Permit is issued.**