

CABINET HEATERS								
TAG	MANUFACTURER	MODEL #	VOLTAGE	PHASE	MCA	GPM	BTU	NOTES
CU-1	SMITH	PSU-10	115	1	>2	2	6,810	
CU-2	SMITH	PSU-10	115	1	>2	2	6,810	

EXHAUST FANS							
TAG	MANUFACTURER	MODEL #	CFM	VOLTS	PHASE	FLA AMPS	NOTES
EF-1	PANASONIC	FV-08VQ5	62 @ .25				ALL BATHROOMS
KEF-1	CAPTIVEAIRE	NCA16HPFA	2250 @ 1.5	230	1	6.8	
DEF-1	CAPTIVEAIRE	DU33HFA	800 @ .25	115	1	4.4	


ENERGY RECOVERY VENTILATORS							
TAG	MFG	MODEL #	VOLT	FLA	MCA	CFM	NOTES
ERV-1	RENEW AIRE	EV450RT				450 @ .5	

SPLIT SYSTEM												
TAG	MFG	INDOOR MODEL	COOLING BTU'S	HEATING BTU'S	CFM	TAG	OUTDOOR MODEL	VOLTS	PHASE	MCA	MAX FUSE	NOTES
AC-A-2	DAIKIN	FTXS12LVJU	✓		440	CU-A	2MXL18QMVJU	208/230	1			
AC-A-1	DAIKIN	CTXS07LVJU	✓		350	CU-A	2MXL18QMVJU	208/230	1			
AC-1-BASE	DAIKIN	FTXS15LVJU	✓		420	CU-BASE	RXL15QMVJU	208/230	1			
AC-B-2	DAIKIN	FTXS12LVJU	✓		440	CU-B	2MXL18QMVJU	208/230	1			
AC-B-1	DAIKIN	CTXS07LVJU	✓		350	CU-B	2MXL18QMVJU	208/230	1			
AC-C	DAIKIN	FTXS09LVJU	✓		420	CU-C	RXL09QMVJU	208/230	1			
AC-D	DAIKIN	FTXS12LVJU	✓		440	CU-D	RXL12QMVJU	208/230	1			
AC-1-2	DAIKIN	FTXS09LVJU	✓		420	CU-1	2MXL18QMVJU	208/230	1			
AC-1-1	DAIKIN	FTXS15LVJU	✓		600	CU-1	2MXL18QMVJU	208/230	1			
AC-E-2	DAIKIN	CTXS07LVJU	✓		350	CU-E	2MXL18QMVJU	208/230	1			
AC-E-1	DAIKIN	FTXS12LVJU	✓		440	CU-E	2MXL18QMVJU	208/230	1			
AC-F	DAIKIN	FTXS09LVJU	✓		420	CU-F	RXL09QMVJU	208/230	1			
AC-G	DAIKIN	FTXS12LVJU	✓		440	CU-G	RXL12QMVJU	208/230	1			
AC-J	DAIKIN	FTXS09LVJU	✓		420	CU-J	RXL09QMVJU	208/230	1			
AC-K	DAIKIN	FTXS09LVJU	✓		420	CU-K	RXL09QMVJU	208/230	1			
AC-2-1	DAIKIN	CTXS07LVJU	✓		350	CU-2	2MXL18QMVJU	208/230	1			
AC-2-2	DAIKIN	CTXS07LVJU	✓		350	CU-2	2MXL18QMVJU	208/230	1			
AC-L	DAIKIN	FTXS15LVJU	✓		420	CU-L	RXL15QMVJU	208/230	1			
AC-H	DAIKIN	FTXS09LVJU	✓		420	CU-H	RXL09QMVJU	208/230	1			
AC-I	DAIKIN	FTXS09LVJU	✓		420	CU-I	RXL09QMVJU	208/230	1			
AC-O	DAIKIN	FTXS15LVJU	✓		440	CU-O	RXL15QMVJU	208/230	1			
AC-P	DAIKIN	FTXS15LVJU	✓		440	CU-P	RXL15QMVJU	208/230	1			
AC-N	DAIKIN	FTXS12LVJU	✓		440	CU-N	RXL12QMVJU	208/230	1			
AC-M	DAIKIN	FTXS09LVJU	✓		420	CU-M	RXL09QMVJU	208/230	1			

ROOFTOP UNIT									
TAG	MFG	MODEL #	HTG (BTU)	CLG (BTU)	VOLT	PHASE	MCA	MAX FUSE	NOTES
RTU-1	TRANE	YSC060M3	120,000	60,000	208	3	27.4	40	

PUMPS							
TAG	MFG	MODEL #	GPM	VOLT	PHASE	MCA	NOTES
P-1	GRUNDFOS	MAGNA 14-80	40	115	1	2.52	

BOILER								
TAG	MFG	MODEL #	INPUT BTU	OUTPUT BTU	VOLT	PHASE	MCA	NOTES
B-1	NTI	TFT-250	250,000	230,000	120	1	12	

 <p>Design • Build • Install • Service</p> <p>73 BRADLEY DRIVE WESTBROOK, MAINE 04092 (207) 854-HVAC (4822)</p>	<p>REVISIONS</p> <table border="1"> <thead> <tr> <th>NO.</th> <th>NOTES</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> </tr> </tbody> </table>	NO.	NOTES			<p>FRANCIS HOTEL</p> <p>747 CONGRESS ST. PORTLAND, MAINE</p> <p>PROJECT SCHEDULES</p>
	NO.	NOTES				
<p>SHEET TITLE:</p> <p>SCALE: NTS</p> <p>DRAWN BY: TJF</p> <p>CHECKED BY:</p> <p>XX</p>	<p>DATE: 3-23-2017</p> <p>SHEET No.</p> <p>M-5</p>					