

Fire Suppression System Design Specifications

Notes

System Materials

Item Number	Description	Quantity
87-120016-001	ADP Nozzle	3
WK-282664-000	ML-360 Link 360 F (182 C), ML, Unpaint	3
87-120019-001	R Nozzle	4
87-120017-001	F Nozzle	1
87-120018-001	GRW Nozzle	1
WK-282666-000	ML-500 Link 500 F (260 C), ML, Orange	3
60-120006-001	WHDR-400M Cylinder/Valve, 4 Gallon	1
60-120099-001	Universal Control Head Assembly	1
60-120110-001	Remote Manual Release, Combination	1
60-120071-001	3/4" NPT Mechanical Gas Valve	1



Designed & Installed by:
Firesafe Equipment
Po Box 1355
Auburn, ME 04211
207-784-7525

For:
FRANCIS INN