Tread and Riser Dimensions

CITY OF PORTLAND, MAINE · RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/16/14

Headroom at opening – 7'

Handrails – 36"

Baluster spacing – 3"